
LUMINAIRE PHOTOMETRIC TEST REPORT

Test:U:24.00V I:0.5629A P:13.51W PF:0 Lamp Flux:900.231x1 lm		
NAME: HCP-3925144	TYPE:	WEIGHT:
DIM.:	SPEC.:	SERIAL No.:1
MFR.: HAVIT COMMERCIAL	SUR.:0.008	PROTECTION ANGLE:


DATA OF LAMP		PHOTOMETRIC DATA		Eff: 66.64 lm/W	
MODEL	4000K	Imax(cd)	236.4	S/MH(C0/180)	1.52
NOMINAL POWER(W)	14.4	LOR(%)	100.0	S/MH(C90/270)	1.40
RATED VOLTAGE(V)	24	TOTAL FLUX(lm)	900.23	η UP,DN(C0-180)	0.0,55.7
NOMINAL FLUX(lm)	900.231	CIE CLASS	DIRECT	η UP,DN(C180-360)	0.0,44.3
LAMPS INSIDE	1	η up(%)	0.0	CIBSE SHR NOM	1.50
TEST VOLTAGE(V)	24	η down(%)	100.0	CIBSE SHR MAX	1.55

LUMINOUS INTENSITY DISTRIBUTION DIAGRAM



AVERAGE BEAM ANGLE(50%):141.3 DEG

C0 PLANE ISOLUX DIAGRAM (UNIT:lx)



C Range: 0 - 360DEG
C Interval: 90.0DEG
Test Speed: HIGH
Temperature:25.3DEG
Operators:QUAN
Test Date:2022-12-28

γ Range: 0 - 90DEG
γ Interval: 1.0DEG
Test System:EVERFINE GO-2000B_V1 SYSTEM V2.0.270
Humidity:65.0%
Test Distance:8.140m [K=1.0000]
Remarks:

ZONAL FLUX DIAGRAM

ZONAL FLUX DIAGRAM:

γ	C0	C90	C180	C270					γ	Φ zone	Φ total	%lum,lamp
10	235.3	229.9	222.4	229.7					0- 10	21.95	21.95	2.44,2.44
20	236.3	225.7	210.6	225.8					10- 20	64.37	86.32	9.59,9.59
30	233.1	215.7	195.9	216.2					20- 30	101.8	188.1	20.9,20.9
40	226.3	199.8	177.6	200.7					30- 40	130.8	319.0	35.4,35.4
50	215.2	177.2	155.8	178.3					40- 50	148.4	467.4	51.9,51.9
60	200.8	144.2	114.9	147.1					50- 60	149.7	617.1	68.6,68.6
70	167.0	94.02	82.11	104.2					60- 70	131.1	748.3	83.1,83.1
80	147.6	33.54	45.92	51.76					70- 80	96.27	844.5	93.8,93.8
90	125.9	1.296	16.44	5.212					80- 90	55.71	900.2	100,100
100									90-100			
110									100-110			
120									110-120			
130									120-130			
140									130-140			
150									140-150			
160									150-160			
170									160-170			
180									170-180			
DEG	LUMINOUS INTENSITY:cd									UNIT:lm		


C Range: 0 - 360DEG
C Interval: 90.0DEG
Test Speed: HIGH
Temperature:25.3DEG
Operators:QUAN
Test Date:2022-12-28

γ Range: 0 - 90DEG
γ Interval: 1.0DEG
Test System:EVERFINE GO-2000B_V1 SYSTEM V2.0.270
Humidity:65.0%
Test Distance:8.140m [K=1.0000]
Remarks:

CU AND LUMINAIRE BUDGETARY ESTIMATE DIAGRAM

Test:U:24.00V I:0.5629A P:13.51W PF:0 Lamp Flux:900.231x1 lm		
NAME: HCP-3925144	TYPE:	WEIGHT:
DIM.:	SPEC.:	SERIAL No.:1
MFR.: HAVIT COMMERCIAL	SUR.:0.008	PROTECTION ANGLE:

ρcc	80%			70%			50%			30%			10%			0
ρw	50%	30%	10%	50%	30%	10%	50%	30%	10%	50%	30%	10%	50%	30%	10%	0
ρfc	20%			20%			20%			20%			20%			0
RCR	RCR:Room Cavity Ratio			Coefficients of Utilization(CU)												
0.0	1.19	1.19	1.19	1.16	1.16	1.16	1.11	1.11	1.11	1.06	1.06	1.06	1.02	1.02	1.02	1.00
1.0	1.00	.95	.90	.98	.93	.89	.93	.89	.86	.89	.86	.83	.86	.83	.80	.78
2.0	.85	.77	.71	.84	.76	.70	.80	.74	.68	.76	.71	.67	.73	.69	.65	.63
3.0	.74	.65	.57	.72	.64	.57	.69	.62	.56	.66	.60	.55	.64	.58	.54	.51
4.0	.65	.55	.48	.63	.54	.47	.61	.53	.46	.58	.51	.46	.56	.50	.45	.43
5.0	.57	.48	.40	.56	.47	.40	.54	.46	.40	.52	.45	.39	.50	.44	.39	.36
6.0	.51	.42	.35	.50	.41	.35	.48	.40	.34	.47	.39	.34	.45	.39	.33	.31
7.0	.46	.37	.30	.45	.37	.30	.44	.36	.30	.42	.35	.30	.41	.34	.29	.27
8.0	.42	.33	.27	.41	.33	.27	.40	.32	.26	.39	.32	.26	.37	.31	.26	.24
9.0	.38	.30	.24	.38	.30	.24	.37	.29	.24	.36	.29	.24	.34	.28	.23	.21
10.0	.35	.27	.22	.35	.27	.21	.34	.26	.21	.33	.26	.21	.32	.26	.21	.19



C Range: 0 - 360DEG
C Interval: 90.0DEG
Test Speed: HIGH
Temperature:25.3DEG
Operators:QUAN
Test Date:2022-12-28

γ Range: 0 - 90DEG
γ Interval: 1.0DEG
Test System:EVERFINE GO-2000B_V1 SYSTEM V2.0.270
Humidity:65.0%
Test Distance:8.140m [K=1.0000]
Remarks:

WEC AND CCEC

Test:U:24.00V I:0.5629A P:13.51W PF:0 Lamp Flux:900.231x1 lm		
NAME: HCP-3925144	TYPE:	WEIGHT:
DIM.:	SPEC.:	SERIAL No.:1
MFR.: HAVIT COMMERCIAL	SUR.:0.008	PROTECTION ANGLE:

ρcc	80%			70%			50%			30%			10%			0
ρw	50%	30%	10%	50%	30%	10%	50%	30%	10%	50%	30%	10%	50%	30%	10%	0
ρfc	20%			20%			20%			20%			20%			0
RCR	RCR:Room Cavity Ratio						Wall Exitance Coeffcients(WEC)									
0.0																
1.0	.382	.217	.069	.375	.214	.068	.361	.207	.066	.349	.201	.065	.337	.195	.063	
2.0	.339	.186	.057	.333	.183	.056	.321	.178	.055	.310	.174	.054	.299	.169	.053	
3.0	.305	.162	.049	.299	.160	.048	.288	.156	.047	.278	.152	.047	.269	.149	.046	
4.0	.275	.143	.042	.270	.141	.042	.261	.138	.041	.252	.135	.041	.244	.132	.040	
5.0	.251	.128	.037	.246	.126	.037	.238	.124	.036	.230	.121	.036	.223	.119	.036	
6.0	.230	.115	.033	.226	.114	.033	.219	.112	.033	.212	.110	.032	.205	.108	.032	
7.0	.212	.105	.030	.209	.104	.030	.202	.102	.029	.196	.100	.029	.190	.099	.029	
8.0	.197	.096	.027	.194	.095	.027	.188	.094	.027	.182	.092	.027	.177	.091	.026	
9.0	.183	.089	.025	.181	.088	.025	.175	.087	.025	.170	.085	.024	.165	.084	.024	
10.0	.172	.082	.023	.169	.082	.023	.164	.080	.023	.160	.079	.023	.155	.078	.022	

ρcc	80%			70%			50%			30%			10%			0
ρw	50%	30%	10%	50%	30%	10%	50%	30%	10%	50%	30%	10%	50%	30%	10%	0
ρfc	20%			20%			20%			20%			20%			0
RCR	RCR:Room Cavity Ratio						Ceiling Cavity Exitance Coefficients(CCEC)									
0.0	.190	.190	.190	.163	.163	.163	.111	.111	.111	.064	.064	.064	.020	.020	.020	
1.0	.185	.155	.129	.159	.133	.111	.108	.092	.077	.062	.053	.045	.020	.017	.014	
2.0	.179	.132	.092	.153	.113	.080	.105	.078	.056	.060	.046	.033	.019	.015	.011	
3.0	.171	.115	.069	.147	.099	.060	.101	.069	.042	.058	.040	.025	.019	.013	.008	
4.0	.163	.102	.054	.140	.088	.047	.096	.061	.033	.056	.036	.020	.018	.012	.006	
5.0	.155	.091	.044	.134	.079	.038	.092	.055	.027	.053	.032	.016	.017	.011	.005	
6.0	.148	.083	.037	.127	.072	.032	.088	.050	.023	.051	.030	.013	.016	.010	.004	
7.0	.141	.076	.031	.121	.066	.027	.084	.046	.019	.049	.027	.012	.016	.009	.004	
8.0	.134	.071	.027	.115	.061	.024	.080	.043	.017	.046	.025	.010	.015	.008	.003	
9.0	.127	.066	.024	.109	.057	.021	.076	.040	.015	.044	.024	.009	.014	.008	.003	
10.0	.121	.061	.022	.104	.053	.019	.072	.037	.013	.042	.022	.008	.014	.007	.003	

C Range: 0 - 360DEG
C Interval: 90.0DEG
Test Speed: HIGH
Temperature:25.3DEG
Operators:QUAN
Test Date:2022-12-28

γ Range: 0 - 90DEG
γ Interval: 1.0DEG
Test System:EVERFINE GO-2000B_V1 SYSTEM V2.0.270
Humidity:65.0%
Test Distance:8.140m [K=1.0000]
Remarks:

Uncorrected UGR Table

Test:U:24.00V I:0.5629A P:13.51W PF:0 Lamp Flux:900.231x1 lm		
NAME: HCP-3925144	TYPE:	WEIGHT:
DIM.:	SPEC.:	SERIAL No.:1
MFR.: HAVIT COMMERCIAL	SUR.:0.008	PROTECTION ANGLE:

ceiling/cavity		0.7	0.7	0.5	0.5	0.3	0.7	0.7	0.5	0.5	0.3
walls		0.5	0.3	0.5	0.3	0.3	0.5	0.3	0.5	0.3	0.3
working plane		0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2
Room dimensions		Viewed crosswise					Viewed endwise				
x = 2H	y = 2H	26.9	28.6	27.2	28.8	29.0	25.7	27.4	26.0	27.6	27.8
	3H	29.4	31.0	29.7	31.2	31.5	27.5	29.0	27.8	29.3	29.5
	4H	30.9	32.4	31.2	32.6	32.9	28.2	29.7	28.5	29.9	30.2
	6H	32.6	34.0	32.9	34.2	34.5	28.6	30.0	29.0	30.3	30.6
	8H	33.5	34.9	33.8	35.1	35.4	28.7	30.1	29.1	30.4	30.7
	12H	34.6	35.9	35.0	36.2	36.5	28.7	30.0	29.1	30.3	30.7
4H	2H	27.6	29.1	27.9	29.3	29.6	26.7	28.2	27.0	28.4	28.7
	3H	30.3	31.6	30.7	31.9	32.2	28.7	30.0	29.1	30.3	30.6
	4H	31.9	33.1	32.3	33.5	33.8	29.6	30.8	30.0	31.1	31.5
	6H	33.8	34.9	34.2	35.2	35.6	30.2	31.3	30.6	31.7	32.0
	8H	34.8	35.9	35.3	36.2	36.6	30.4	31.4	30.8	31.8	32.2
	12H	36.1	37.0	36.5	37.4	37.8	30.5	31.4	30.9	31.8	32.2
8H	4H	32.3	33.3	32.7	33.7	34.1	30.4	31.4	30.8	31.7	32.1
	6H	34.4	35.3	34.8	35.7	36.1	31.3	32.2	31.7	32.6	33.0
	8H	35.6	36.4	36.1	36.8	37.3	31.6	32.4	32.1	32.8	33.3
	12H	37.1	37.8	37.6	38.3	38.7	31.8	32.5	32.3	33.0	33.5
12H	4H	32.3	33.3	32.8	33.7	34.1	30.6	31.5	31.0	31.9	32.3
	6H	34.5	35.3	35.0	35.7	36.2	31.7	32.5	32.2	32.9	33.4
	8H	35.8	36.5	36.3	37.0	37.4	32.2	32.8	32.7	33.3	33.8

Variations with the observer position at spacings:		
S = 1.0H	+ 0.1 / - 0.1	+ 0.1 / - 0.1
1.5H	+ 0.2 / - 0.2	+ 0.2 / - 0.3
2.0H	+ 0.2 / - 0.3	+ 0.3 / - 0.5

CIE Pub.117 Corrected 900.2 lm Total Lamp Luminous Flux.(8log(F/F0) = -0.4)

C Range: 0 - 360DEG
C Interval: 90.0DEG
Test Speed: HIGH
Temperature:25.3DEG
Operators:QUAN
Test Date:2022-12-28

γ Range: 0 - 90DEG
γ Interval: 1.0DEG
Test System:EVERFINE GO-2000B_V1 SYSTEM V2.0.270
Humidity:65.0%
Test Distance:8.140m [K=1.0000]
Remarks:

UTILIZATION FACTORS TABLE

Test:U:24.00V I:0.5629A P:13.51W PF:0 Lamp Flux:900.231x1 lm		
NAME: HCP-3925144	TYPE:	WEIGHT:
DIM.:	SPEC.:	SERIAL No.:1
MFR.: HAVIT COMMERCIAL	SUR.:0.008	PROTECTION ANGLE:


REFLECTANCE										
Ceiling	0.8	0.8	0.8	0.7	0.7	0.7	0.5	0.5	0.5	0
Walls	0.7	0.5	0.3	0.7	0.5	0.3	0.7	0.5	0.3	0
Working plane	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0
ROOM INDEX	UTILIZATION FACTORS(PERCENT) k(RI) x RCR = 5									
k = 0.60	53	40	32	52	40	32	50	39	32	25
0.80	62	49	41	61	49	41	59	48	41	33
1.00	70	58	50	69	57	50	67	59	49	41
1.25	78	66	58	76	65	57	73	63	56	48
1.50	83	71	63	81	71	63	78	69	62	53
2.00	90	80	73	88	79	72	85	77	70	62
2.50	95	85	78	92	84	77	88	81	75	66
3.00	98	90	83	96	88	82	92	85	80	71
4.00	103	96	90	100	94	89	96	91	86	77
5.00	106	100	95	103	98	93	98	94	90	80
ROOM INDEX	UF(total)									Direct
According to DIN EN 13032-2 2004				Suspended					SHRNOM = 1.25	

C Range: 0 - 360DEG
C Interval: 90.0DEG
Test Speed: HIGH
Temperature:25.3DEG
Operators:QUAN
Test Date:2022-12-28

γ Range: 0 - 90DEG
γ Interval: 1.0DEG
Test System:EVERFINE GO-2000B_V1 SYSTEM V2.0.270
Humidity:65.0%
Test Distance:8.140m [K=1.0000]
Remarks:

ISOCANDELA DIAGRAM

Test:U:24.00V I:0.5629A P:13.51W PF:0 Lamp Flux:900.231x1 lm		
NAME: HCP-3925144	TYPE:	WEIGHT:
DIM.:	SPEC.:	SERIAL No.:1
MFR.: HAVIT COMMERCIAL	SUR.:0.008	PROTECTION ANGLE:




C Range: 0 - 360DEG
C Interval: 90.0DEG
Test Speed: HIGH
Temperature:25.3DEG
Operators:QUAN
Test Date:2022-12-28

γ Range: 0 - 90DEG
γ Interval: 1.0DEG
Test System:EVERFINE GO-2000B_V1 SYSTEM V2.0.270
Humidity:65.0%
Test Distance:8.140m [K=1.0000]
Remarks:

AAI Figure

Test:U:24.00V I:0.5629A P:13.51W PF:0 Lamp Flux:900.231x1 lm		
NAME: HCP-3925144	TYPE:	WEIGHT:
DIM.:	SPEC.:	SERIAL No.:1
MFR.: HAVIT COMMERCIAL	SUR.:0.008	PROTECTION ANGLE:




Note:The Curves indicate the illuminated area and the average illumination when the luminaire is at different distance.

C Range: 0 - 360DEG
C Interval: 90.0DEG
Test Speed: HIGH
Temperature:25.3DEG
Operators:QUAN
Test Date:2022-12-28

γ Range: 0 - 90DEG
γ Interval: 1.0DEG
Test System:EVERFINE GO-2000B_V1 SYSTEM V2.0.270
Humidity:65.0%
Test Distance:8.140m [K=1.0000]
Remarks:

ISOLUX DIAGRAM


Test:U:24.00V I:0.5629A P:13.51W PF:0 Lamp Flux:900.231x1 lm		
NAME: HCP-3925144	TYPE:	WEIGHT:
DIM.:	SPEC.:	SERIAL No.:1
MFR.: HAVIT COMMERCIAL	SUR.:0.008	PROTECTION ANGLE:



C Range: 0 - 360DEG
C Interval: 90.0DEG
Test Speed: HIGH
Temperature:25.3DEG
Operators:QUAN
Test Date:2022-12-28

γ Range: 0 - 90DEG
γ Interval: 1.0DEG
Test System:EVERFINE GO-2000B_V1 SYSTEM V2.0.270
Humidity:65.0%
Test Distance:8.140m [K=1.0000]
Remarks:

Planar Illuminance Curve



C Range: 0 - 360DEG
C Interval: 90.0DEG
Test Speed: HIGH
Temperature:25.3DEG
Operators:QUAN
Test Date:2022-12-28

γ Range: 0 - 90DEG
γ Interval: 1.0DEG
Test System:EVERFINE GO-2000B_V1 SYSTEM V2.0.270
Humidity:65.0%
Test Distance:8.140m [K=1.0000]
Remarks:

LUMINOUS DISTRIBUTION INTENSITY DATA

Test:U:24.00V I:0.5629A P:13.51W PF:0 Lamp Flux:900.231x1 lm		
NAME: HCP-3925144	TYPE:	WEIGHT:
DIM.:	SPEC.:	SERIAL No.:1
MFR.: HAVIT COMMERCIAL	SUR.:0.008	PROTECTION ANGLE:

Table--1 UNIT: cd

γ (DEG) \ C(DEG)	0	90	180	270
0	231	230	231	230
5	234	230	227	230
10	235	230	222	230
15	236	228	217	228
20	236	226	211	226
25	235	221	204	222
30	233	216	196	216
35	230	209	187	209
40	226	200	178	201
45	221	189	167	191
50	215	177	156	178
55	208	163	132	164
60	201	144	115	147
65	181	121	99.6	127
70	167	94.0	82.1	104
75	158	64.3	64.6	78.9
80	148	33.5	45.9	51.8
85	138	4.79	30.3	25.9
90	126	1.30	16.4	5.21

C Range: 0 - 360DEG
C Interval: 90.0DEG
Test Speed: HIGH
Temperature:25.3DEG
Operators:QUAN
Test Date:2022-12-28

γ Range: 0 - 90DEG
γ Interval: 1.0DEG
Test System:EVERFINE GO-2000B_V1 SYSTEM V2.0.270
Humidity:65.0%
Test Distance:8.140m [K=1.0000]
Remarks: