
LUMINAIRE PHOTOMETRIC TEST REPORT

Test:U:24.00V I:0.6030A P:14.48W PF:1.000 Lamp Flux:990.871x1 lm		
NAME: HCP-3955145	TYPE:	WEIGHT:
DIM.:	SPEC.:	SERIAL No.:1
MFR.: HAVIT COMMERCIAL	SUR.:0.008	PROTECTION ANGLE:


DATA OF LAMP		PHOTOMETRIC DATA		Eff: 68.43 lm/W	
MODEL	5000K	Imax(cd)	256.3	S/MH(C0/180)	1.37
NOMINAL POWER(W)	14.4	LOR(%)	100.0	S/MH(C90/270)	1.28
RATED VOLTAGE(V)	24	TOTAL FLUX(lm)	990.87	η UP,DN(C0-180)	0.0,44.4
NOMINAL FLUX(lm)	990.871	CIE CLASS	DIRECT	η UP,DN(C180-360)	0.0,55.6
LAMPS INSIDE	1	η up(%)	0.0	CIBSE SHR NOM	1.50
TEST VOLTAGE(V)	219.8	η down(%)	100.0	CIBSE SHR MAX	1.55

LUMINOUS INTENSITY DISTRIBUTION DIAGRAM



AVERAGE BEAM ANGLE(50%):148.6 DEG

C0 PLANE ISOLUX DIAGRAM (UNIT:lx)



C Range: 0 - 360DEG
C Interval: 90.0DEG
Test Speed: HIGH
Temperature:25.3DEG
Operators:QUAN
Test Date:2022-12-29

γ Range: 0 - 90DEG
γ Interval: 1.0DEG
Test System:EVERFINE GO-2000B_V1 SYSTEM V2.0.270
Humidity:65.0%
Test Distance:8.140m [K=1.0000]
Remarks:

ZONAL FLUX DIAGRAM

ZONAL FLUX DIAGRAM:

γ	C0	C90	C180	C270					γ	Φ zone	Φ total	%lum,lamp
10	254.4	188.1	256.1	215.8					0- 10	21.83	21.83	2.2,2.2
20	247.9	178.8	249.9	218.3					10- 20	64.27	86.10	8.69,8.69
30	234.3	175.0	238.2	212.5					20- 30	101.7	187.8	19,19
40	218.1	152.3	222.9	202.9					30- 40	130.0	317.8	32.1,32.1
50	207.3	131.2	207.1	188.5					40- 50	148.3	466.1	47,47
60	194.6	105.1	192.9	171.4					50- 60	156.4	622.5	62.8,62.8
70	207.5	76.27	200.2	147.8					60- 70	161.5	784.0	79.1,79.1
80	95.48	29.18	128.0	115.8					70- 80	134.8	918.7	92.7,92.7
90	48.97	1.610	56.30	91.66					80- 90	72.13	990.9	100,100
100									90-100			
110									100-110			
120									110-120			
130									120-130			
140									130-140			
150									140-150			
160									150-160			
170									160-170			
180									170-180			
DEG	LUMINOUS INTENSITY:cd									UNIT:lm		


C Range: 0 - 360DEG
C Interval: 90.0DEG
Test Speed: HIGH
Temperature:25.3DEG
Operators:QUAN
Test Date:2022-12-29

γ Range: 0 - 90DEG
γ Interval: 1.0DEG
Test System:EVERFINE GO-2000B_V1 SYSTEM V2.0.270
Humidity:65.0%
Test Distance:8.140m [K=1.0000]
Remarks:

CU AND LUMINAIRE BUDGETARY ESTIMATE DIAGRAM

Test:U:24.00V I:0.6030A P:14.48W PF:1.000 Lamp Flux:990.871x1 lm		
NAME: HCP-3955145	TYPE:	WEIGHT:
DIM.:	SPEC.:	SERIAL No.:1
MFR.: HAVIT COMMERCIAL	SUR.:0.008	PROTECTION ANGLE:

ρcc	80%			70%			50%			30%			10%			0
ρw	50%	30%	10%	50%	30%	10%	50%	30%	10%	50%	30%	10%	50%	30%	10%	0
ρfc	20%			20%			20%			20%			20%			0
RCR	RCR:Room Cavity Ratio			Coefficients of Utilization(CU)												
0.0	1.19	1.19	1.19	1.16	1.16	1.16	1.11	1.11	1.11	1.06	1.06	1.06	1.02	1.02	1.02	1.00
1.0	.99	.93	.88	.96	.91	.86	.92	.87	.83	.88	.84	.81	.84	.81	.78	.76
2.0	.83	.75	.68	.81	.73	.67	.78	.71	.65	.74	.68	.64	.71	.66	.62	.60
3.0	.72	.62	.54	.70	.61	.53	.67	.59	.52	.64	.57	.51	.61	.55	.50	.48
4.0	.62	.52	.44	.61	.51	.44	.58	.50	.43	.56	.49	.43	.54	.47	.42	.40
5.0	.55	.45	.37	.54	.44	.37	.52	.43	.37	.50	.42	.36	.48	.41	.36	.33
6.0	.49	.39	.32	.48	.39	.32	.46	.38	.32	.45	.37	.31	.43	.36	.31	.29
7.0	.44	.35	.28	.43	.34	.28	.42	.34	.28	.40	.33	.27	.39	.32	.27	.25
8.0	.40	.31	.25	.40	.31	.25	.38	.30	.24	.37	.30	.24	.36	.29	.24	.22
9.0	.37	.28	.22	.36	.28	.22	.35	.27	.22	.34	.27	.22	.33	.26	.21	.19
10.0	.34	.25	.20	.33	.25	.20	.32	.25	.20	.31	.24	.19	.30	.24	.19	.17



C Range: 0 - 360DEG
C Interval: 90.0DEG
Test Speed: HIGH
Temperature:25.3DEG
Operators:QUAN
Test Date:2022-12-29

γ Range: 0 - 90DEG
γ Interval: 1.0DEG
Test System:EVERFINE GO-2000B_V1 SYSTEM V2.0.270
Humidity:65.0%
Test Distance:8.140m [K=1.0000]
Remarks:

WEC AND CCEC

Test:U:24.00V I:0.6030A P:14.48W PF:1.000 Lamp Flux:990.871x1 lm		
NAME: HCP-3955145	TYPE:	WEIGHT:
DIM.:	SPEC.:	SERIAL No.:1
MFR.: HAVIT COMMERCIAL	SUR.:0.008	PROTECTION ANGLE:

ρcc	80%			70%			50%			30%			10%			0
ρw	50%	30%	10%	50%	30%	10%	50%	30%	10%	50%	30%	10%	50%	30%	10%	0
ρfc	20%			20%			20%			20%			20%			0
RCR	RCR:Room Cavity Ratio						Wall Exitance Coeffcients(WEC)									
0.0																
1.0	.412	.234	.074	.404	.231	.073	.391	.224	.072	.378	.218	.070	.366	.212	.068	
2.0	.361	.198	.061	.354	.195	.060	.342	.190	.059	.330	.185	.058	.320	.181	.057	
3.0	.320	.170	.051	.314	.168	.051	.303	.164	.050	.293	.161	.049	.284	.157	.049	
4.0	.287	.149	.044	.282	.147	.044	.272	.144	.043	.263	.141	.043	.255	.138	.042	
5.0	.260	.132	.038	.255	.131	.038	.247	.128	.038	.239	.126	.037	.231	.123	.037	
6.0	.237	.119	.034	.233	.118	.034	.225	.115	.034	.218	.113	.033	.211	.111	.033	
7.0	.218	.108	.031	.214	.107	.030	.207	.105	.030	.201	.103	.030	.195	.101	.030	
8.0	.201	.098	.028	.198	.098	.028	.192	.096	.027	.186	.094	.027	.181	.093	.027	
9.0	.187	.090	.025	.184	.090	.025	.179	.088	.025	.174	.087	.025	.169	.086	.025	
10.0	.175	.084	.023	.172	.083	.023	.167	.082	.023	.163	.081	.023	.158	.080	.023	

ρcc	80%			70%			50%			30%			10%			0
ρw	50%	30%	10%	50%	30%	10%	50%	30%	10%	50%	30%	10%	50%	30%	10%	0
ρfc	20%			20%			20%			20%			20%			0
RCR	RCR:Room Cavity Ratio						Ceiling Cavity Exitance Coefficients(CCEC)									
0.0	.190	.190	.190	.163	.163	.163	.111	.111	.111	.064	.064	.064	.020	.020	.020	
1.0	.187	.155	.126	.160	.133	.109	.110	.092	.075	.063	.053	.044	.020	.017	.014	
2.0	.181	.132	.090	.155	.113	.078	.106	.078	.054	.061	.046	.032	.020	.015	.010	
3.0	.174	.115	.067	.149	.099	.058	.102	.069	.041	.059	.040	.024	.019	.013	.008	
4.0	.166	.102	.053	.143	.088	.046	.098	.061	.032	.057	.036	.019	.018	.012	.006	
5.0	.158	.092	.043	.136	.079	.037	.094	.055	.026	.054	.033	.016	.017	.011	.005	
6.0	.150	.084	.036	.129	.072	.031	.089	.051	.022	.052	.030	.013	.017	.010	.004	
7.0	.143	.077	.031	.123	.067	.027	.085	.047	.019	.049	.027	.011	.016	.009	.004	
8.0	.135	.071	.027	.117	.062	.023	.081	.043	.017	.047	.025	.010	.015	.008	.003	
9.0	.129	.066	.024	.111	.057	.021	.077	.040	.015	.045	.024	.009	.014	.008	.003	
10.0	.122	.062	.021	.105	.054	.019	.073	.038	.013	.043	.022	.008	.014	.007	.003	

C Range: 0 - 360DEG
C Interval: 90.0DEG
Test Speed: HIGH
Temperature:25.3DEG
Operators:QUAN
Test Date:2022-12-29

γ Range: 0 - 90DEG
γ Interval: 1.0DEG
Test System:EVERFINE GO-2000B_V1 SYSTEM V2.0.270
Humidity:65.0%
Test Distance:8.140m [K=1.0000]
Remarks:

Uncorrected UGR Table

Test:U:24.00V I:0.6030A P:14.48W PF:1.000 Lamp Flux:990.871x1 lm		
NAME: HCP-3955145	TYPE:	WEIGHT:
DIM.:	SPEC.:	SERIAL No.:1
MFR.: HAVIT COMMERCIAL	SUR.:0.008	PROTECTION ANGLE:

ceiling/cavity	0.7	0.7	0.5	0.5	0.3	0.7	0.7	0.5	0.5	0.3
walls	0.5	0.3	0.5	0.3	0.3	0.5	0.3	0.5	0.3	0.3
working plane	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2
Room dimensions	Viewed crosswise					Viewed endwise				
x = 2H y = 2H	26.2	27.9	26.4	28.1	28.3	23.8	25.5	24.1	25.7	26.0
3H	29.7	31.3	30.0	31.6	31.8	25.9	27.5	26.2	27.8	28.0
4H	31.0	32.5	31.3	32.8	33.0	26.7	28.2	27.0	28.5	28.7
6H	31.8	33.3	32.1	33.5	33.8	27.1	28.6	27.4	28.8	29.1
8H	32.1	33.6	32.5	33.9	34.2	27.2	28.6	27.5	28.9	29.2
12H	32.5	33.9	32.9	34.2	34.5	27.1	28.5	27.5	28.8	29.1
4H 2H	26.9	28.5	27.3	28.7	29.0	25.3	26.9	25.7	27.1	27.4
3H	30.5	31.9	30.9	32.2	32.5	27.6	29.0	28.0	29.3	29.6
4H	31.9	33.1	32.2	33.5	33.8	28.4	29.7	28.8	30.0	30.4
6H	32.8	34.0	33.2	34.3	34.7	28.9	30.1	29.3	30.4	30.8
8H	33.3	34.3	33.7	34.7	35.1	29.0	30.1	29.5	30.5	30.9
12H	33.7	34.7	34.2	35.1	35.5	29.0	30.0	29.5	30.4	30.9
8H 4H	32.1	33.2	32.5	33.5	33.9	29.2	30.3	29.6	30.7	31.1
6H	33.2	34.1	33.7	34.5	35.0	29.9	30.8	30.4	31.2	31.7
8H	33.8	34.6	34.2	35.0	35.5	30.1	30.9	30.6	31.4	31.8
12H	34.4	35.1	34.9	35.6	36.1	30.2	30.9	30.6	31.3	31.8
12H 4H	32.1	33.1	32.5	33.5	33.9	29.3	30.3	29.8	30.7	31.1
6H	33.2	34.1	33.7	34.5	35.0	30.1	30.9	30.6	31.4	31.8
8H	33.9	34.6	34.3	35.0	35.5	30.4	31.1	30.9	31.6	32.0
Variations with the observer position at spacings:										
S = 1.0H	+ 0.1 / - 0.1					+ 0.1 / - 0.1				
1.5H	+ 0.1 / - 0.1					+ 0.2 / - 0.3				
2.0H	+ 0.1 / - 0.1					+ 0.3 / - 0.5				

CIE Pub.117 Corrected 990.9 lm Total Lamp Luminous Flux.(8log(F/F0) = -0.0)

C Range: 0 - 360DEG
C Interval: 90.0DEG
Test Speed: HIGH
Temperature:25.3DEG
Operators:QUAN
Test Date:2022-12-29

γ Range: 0 - 90DEG
γ Interval: 1.0DEG
Test System:EVERFINE GO-2000B_V1 SYSTEM V2.0.270
Humidity:65.0%
Test Distance:8.140m [K=1.0000]
Remarks:

UTILIZATION FACTORS TABLE

Test:U:24.00V I:0.6030A P:14.48W PF:1.000 Lamp Flux:990.871x1 lm		
NAME: HCP-3955145	TYPE:	WEIGHT:
DIM.:	SPEC.:	SERIAL No.:1
MFR.: HAVIT COMMERCIAL	SUR.:0.008	PROTECTION ANGLE:


REFLECTANCE										
Ceiling	0.8	0.8	0.8	0.7	0.7	0.7	0.5	0.5	0.5	0
Walls	0.7	0.5	0.3	0.7	0.5	0.3	0.7	0.5	0.3	0
Working plane	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0
ROOM INDEX	UTILIZATION FACTORS(PERCENT) k(RI) x RCR = 5									
k = 0.60	51	38	31	50	38	30	49	38	30	23
0.80	60	47	39	59	47	39	57	46	38	30
1.00	68	55	47	67	55	46	64	57	46	38
1.25	75	63	54	74	62	54	71	60	53	44
1.50	81	69	60	79	68	59	75	66	58	50
2.00	88	77	69	86	76	69	82	74	67	58
2.50	93	83	75	91	82	74	86	79	73	63
3.00	97	88	81	94	86	80	90	83	78	68
4.00	102	94	88	99	92	87	94	89	84	74
5.00	105	98	93	102	96	91	97	92	88	78
ROOM INDEX	UF(total)									Direct
According to DIN EN 13032-2 2004				Suspended					SHRNOM = 1.25	

C Range: 0 - 360DEG
C Interval: 90.0DEG
Test Speed: HIGH
Temperature:25.3DEG
Operators:QUAN
Test Date:2022-12-29

γ Range: 0 - 90DEG
γ Interval: 1.0DEG
Test System:EVERFINE GO-2000B_V1 SYSTEM V2.0.270
Humidity:65.0%
Test Distance:8.140m [K=1.0000]
Remarks:

ISOCANDELA DIAGRAM

Test:U:24.00V I:0.6030A P:14.48W PF:1.000 Lamp Flux:990.871x1 lm		
NAME: HCP-3955145	TYPE:	WEIGHT:
DIM.:	SPEC.:	SERIAL No.:1
MFR.: HAVIT COMMERCIAL	SUR.:0.008	PROTECTION ANGLE:




C Range: 0 - 360DEG
C Interval: 90.0DEG
Test Speed: HIGH
Temperature:25.3DEG
Operators:QUAN
Test Date:2022-12-29

γ Range: 0 - 90DEG
γ Interval: 1.0DEG
Test System:EVERFINE GO-2000B_V1 SYSTEM V2.0.270
Humidity:65.0%
Test Distance:8.140m [K=1.0000]
Remarks:

AAI CURVES

Test:U:24.00V I:0.6030A P:14.48W PF:1.000 Lamp Flux:990.871x1 lm		
NAME: HCP-3955145	TYPE:	WEIGHT:
DIM.:	SPEC.:	SERIAL No.:1
MFR.: HAVIT COMMERCIAL	SUR.:0.008	PROTECTION ANGLE:




Note:The Curves indicate the illuminated area and the average illumination when the luminaire is at different distance.

C Range: 0 - 360DEG
C Interval: 90.0DEG
Test Speed: HIGH
Temperature:25.3DEG
Operators:QUAN
Test Date:2022-12-29

γ Range: 0 - 90DEG
γ Interval: 1.0DEG
Test System:EVERFINE GO-2000B_V1 SYSTEM V2.0.270
Humidity:65.0%
Test Distance:8.140m [K=1.0000]
Remarks:

ISOLUX DIAGRAM


Test:U:24.00V I:0.6030A P:14.48W PF:1.000 Lamp Flux:990.871x1 lm		
NAME: HCP-3955145	TYPE:	WEIGHT:
DIM.:	SPEC.:	SERIAL No.:1
MFR.: HAVIT COMMERCIAL	SUR.:0.008	PROTECTION ANGLE:



C Range: 0 - 360DEG
C Interval: 90.0DEG
Test Speed: HIGH
Temperature:25.3DEG
Operators:QUAN
Test Date:2022-12-29

γ Range: 0 - 90DEG
γ Interval: 1.0DEG
Test System:EVERFINE GO-2000B_V1 SYSTEM V2.0.270
Humidity:65.0%
Test Distance:8.140m [K=1.0000]
Remarks:

Planar Illuminance Curve



C Range: 0 - 360DEG
C Interval: 90.0DEG
Test Speed: HIGH
Temperature:25.3DEG
Operators:QUAN
Test Date:2022-12-29

γ Range: 0 - 90DEG
γ Interval: 1.0DEG
Test System:EVERFINE GO-2000B_V1 SYSTEM V2.0.270
Humidity:65.0%
Test Distance:8.140m [K=1.0000]
Remarks:

LUMINOUS DISTRIBUTION INTENSITY DATA

Test:U:24.00V I:0.6030A P:14.48W PF:1.000 Lamp Flux:990.871x1 lm		
NAME: HCP-3955145	TYPE:	WEIGHT:
DIM.:	SPEC.:	SERIAL No.:1
MFR.: HAVIT COMMERCIAL	SUR.:0.008	PROTECTION ANGLE:

Table--1 UNIT: cd

γ (DEG) \ C(DEG)	0	90	180	270
0	255	201	255	201
5	255	194	256	210
10	254	188	256	216
15	252	184	254	221
20	248	179	250	218
25	242	177	245	220
30	234	175	238	212
35	226	167	231	208
40	218	152	223	203
45	213	142	215	197
50	207	131	207	188
55	200	118	198	180
60	195	105	193	171
65	212	93.9	178	161
70	208	76.3	200	148
75	151	53.7	180	133
80	95.5	29.2	128	116
85	66.0	3.21	83.0	99.8
90	49.0	1.61	56.3	91.7

C Range: 0 - 360DEG
C Interval: 90.0DEG
Test Speed: HIGH
Temperature:25.3DEG
Operators:QUAN
Test Date:2022-12-29

γ Range: 0 - 90DEG
γ Interval: 1.0DEG
Test System:EVERFINE GO-2000B_V1 SYSTEM V2.0.270
Humidity:65.0%
Test Distance:8.140m [K=1.0000]
Remarks: