
LUMINAIRE PHOTOMETRIC TEST REPORT

Test:U:24.00V I:0.5900A P:14.17W PF:1.000 Lamp Flux:1076.53x1 lm		
NAME: HCP-3965143	TYPE:	WEIGHT:
DIM.:	SPEC.:	SERIAL No.:1
MFR.: HAVIT COMMERCIAL	SUR.:0.008	PROTECTION ANGLE:


DATA OF LAMP		PHOTOMETRIC DATA		Eff: 75.97 lm/W	
MODEL	3000K	Imax(cd)	283.4	S/MH(C0/180)	1.36
NOMINAL POWER(W)	14.4	LOR(%)	100.0	S/MH(C90/270)	1.34
RATED VOLTAGE(V)	24	TOTAL FLUX(lm)	1076.5	η UP,DN(C0-180)	0.0,50.0
NOMINAL FLUX(lm)	1076.53	CIE CLASS	DIRECT	η UP,DN(C180-360)	0.0,50.0
LAMPS INSIDE	1	η up(%)	0.0	CIBSE SHR NOM	1.50
TEST VOLTAGE(V)	14.4	η down(%)	100.0	CIBSE SHR MAX	1.55

LUMINOUS INTENSITY DISTRIBUTION DIAGRAM



AVERAGE BEAM ANGLE(50%):137.9 DEG

C0 PLANE ISOLUX DIAGRAM (UNIT:lx)



C Range: 0 - 360DEG
C Interval: 90.0DEG
Test Speed: HIGH
Temperature:25.3DEG
Operators:QUAN
Test Date:2022-12-29

γ Range: 0 - 90DEG
γ Interval: 1.0DEG
Test System:EVERFINE GO-2000B_V1 SYSTEM V2.0.270
Humidity:65.0%
Test Distance:8.140m [K=1.0000]
Remarks:

ZONAL FLUX DIAGRAM

ZONAL FLUX DIAGRAM:

γ	C0	C90	C180	C270					γ	Φ zone	Φ total	%lum,lamp
10	279.5	280.3	283.1	280.5					0- 10	26.88	26.88	2.5,2.5
20	273.3	272.1	277.6	272.0					10- 20	78.67	105.5	9.8,9.8
30	256.0	255.4	264.7	255.0					20- 30	123.1	228.6	21.2,21.2
40	238.2	230.5	248.1	229.8					30- 40	155.1	383.7	35.6,35.6
50	228.9	197.3	232.9	196.8					40- 50	173.8	557.5	51.8,51.8
60	228.7	156.5	236.4	149.4					50- 60	184.4	741.9	68.9,68.9
70	169.0	105.9	174.8	92.55					60- 70	165.9	907.8	84.3,84.3
80	109.8	47.29	118.7	30.99					70- 80	112.7	1020	94.8,94.8
90	57.64	2.857	66.09	0.6454					80- 90	56.03	1077	100,100
100									90-100			
110									100-110			
120									110-120			
130									120-130			
140									130-140			
150									140-150			
160									150-160			
170									160-170			
180									170-180			
DEG	LUMINOUS INTENSITY:cd									UNIT:lm		


C Range: 0 - 360DEG
C Interval: 90.0DEG
Test Speed: HIGH
Temperature:25.3DEG
Operators:QUAN
Test Date:2022-12-29

γ Range: 0 - 90DEG
γ Interval: 1.0DEG
Test System:EVERFINE GO-2000B_V1 SYSTEM V2.0.270
Humidity:65.0%
Test Distance:8.140m [K=1.0000]
Remarks:

CU AND LUMINAIRE BUDGETARY ESTIMATE DIAGRAM

Test:U:24.00V I:0.5900A P:14.17W PF:1.000 Lamp Flux:1076.53x1 lm		
NAME: HCP-3965143	TYPE:	WEIGHT:
DIM.:	SPEC.:	SERIAL No.:1
MFR.: HAVIT COMMERCIAL	SUR.:0.008	PROTECTION ANGLE:

ρcc	80%			70%			50%			30%			10%			0
ρw	50%	30%	10%	50%	30%	10%	50%	30%	10%	50%	30%	10%	50%	30%	10%	0
ρfc	20%			20%			20%			20%			20%			0
RCR	RCR:Room Cavity Ratio			Coefficients of Utilization(CU)												
0.0	1.19	1.19	1.19	1.16	1.16	1.16	1.11	1.11	1.11	1.06	1.06	1.06	1.02	1.02	1.02	1.00
1.0	1.01	.95	.91	.98	.94	.89	.94	.90	.86	.90	.87	.84	.86	.84	.81	.79
2.0	.86	.78	.71	.84	.77	.70	.80	.74	.69	.77	.72	.67	.74	.69	.66	.63
3.0	.74	.65	.58	.73	.64	.57	.70	.62	.56	.67	.60	.55	.64	.59	.54	.52
4.0	.65	.55	.48	.64	.55	.48	.61	.53	.47	.59	.52	.46	.56	.50	.45	.43
5.0	.58	.48	.41	.56	.47	.40	.54	.46	.40	.52	.45	.39	.50	.44	.39	.37
6.0	.52	.42	.35	.51	.41	.35	.49	.40	.34	.47	.40	.34	.45	.39	.34	.31
7.0	.46	.37	.30	.46	.37	.30	.44	.36	.30	.42	.35	.30	.41	.35	.30	.27
8.0	.42	.33	.27	.41	.33	.27	.40	.32	.27	.39	.32	.26	.38	.31	.26	.24
9.0	.39	.30	.24	.38	.30	.24	.37	.29	.24	.36	.29	.24	.35	.28	.24	.22
10.0	.36	.27	.22	.35	.27	.22	.34	.27	.21	.33	.26	.21	.32	.26	.21	.19



C Range: 0 - 360DEG
C Interval: 90.0DEG
Test Speed: HIGH
Temperature:25.3DEG
Operators:QUAN
Test Date:2022-12-29

γ Range: 0 - 90DEG
γ Interval: 1.0DEG
Test System:EVERFINE GO-2000B_V1 SYSTEM V2.0.270
Humidity:65.0%
Test Distance:8.140m [K=1.0000]
Remarks:

WEC AND CCEC

Test:U:24.00V I:0.5900A P:14.17W PF:1.000 Lamp Flux:1076.53x1 lm		
NAME: HCP-3965143	TYPE:	WEIGHT:
DIM.:	SPEC.:	SERIAL No.:1
MFR.: HAVIT COMMERCIAL	SUR.:0.008	PROTECTION ANGLE:

ρcc	80%			70%			50%			30%			10%			0
ρw	50%	30%	10%	50%	30%	10%	50%	30%	10%	50%	30%	10%	50%	30%	10%	0
ρfc	20%			20%			20%			20%			20%			0
RCR	RCR:Room Cavity Ratio						Wall Exitance Coeffcients(WEC)									
0.0																
1.0	.373	.212	.067	.366	.209	.066	.352	.202	.064	.340	.196	.063	.328	.190	.061	
2.0	.335	.184	.056	.329	.181	.056	.317	.176	.055	.305	.171	.054	.295	.167	.053	
3.0	.302	.161	.048	.297	.159	.048	.286	.155	.047	.276	.151	.046	.267	.148	.046	
4.0	.274	.142	.042	.269	.141	.042	.260	.138	.041	.251	.135	.041	.242	.132	.040	
5.0	.250	.127	.037	.246	.126	.037	.237	.123	.036	.229	.121	.036	.222	.119	.036	
6.0	.230	.115	.033	.226	.114	.033	.218	.112	.033	.211	.110	.032	.204	.108	.032	
7.0	.212	.105	.030	.208	.104	.030	.202	.102	.029	.195	.100	.029	.189	.098	.029	
8.0	.197	.096	.027	.193	.095	.027	.187	.094	.027	.182	.092	.027	.176	.091	.026	
9.0	.183	.089	.025	.180	.088	.025	.175	.087	.025	.170	.085	.024	.165	.084	.024	
10.0	.171	.082	.023	.169	.082	.023	.164	.080	.023	.159	.079	.023	.155	.078	.022	

ρcc	80%			70%			50%			30%			10%			0
ρw	50%	30%	10%	50%	30%	10%	50%	30%	10%	50%	30%	10%	50%	30%	10%	0
ρfc	20%			20%			20%			20%			20%			0
RCR	RCR:Room Cavity Ratio						Ceiling Cavity Exitance Coefficients(CCEC)									
0.0	.190	.190	.190	.163	.163	.163	.111	.111	.111	.064	.064	.064	.020	.020	.020	
1.0	.185	.156	.129	.158	.134	.111	.108	.092	.077	.062	.053	.045	.020	.017	.014	
2.0	.178	.132	.093	.152	.113	.080	.105	.078	.056	.060	.046	.033	.019	.015	.011	
3.0	.171	.115	.070	.146	.099	.060	.100	.069	.042	.058	.040	.025	.019	.013	.008	
4.0	.163	.102	.055	.140	.088	.047	.096	.061	.033	.056	.036	.020	.018	.012	.006	
5.0	.155	.091	.044	.133	.079	.038	.092	.055	.027	.053	.032	.016	.017	.011	.005	
6.0	.148	.083	.037	.127	.072	.032	.088	.050	.023	.051	.030	.013	.016	.010	.004	
7.0	.140	.076	.031	.121	.066	.027	.083	.046	.019	.048	.027	.012	.016	.009	.004	
8.0	.133	.071	.027	.115	.061	.024	.079	.043	.017	.046	.025	.010	.015	.008	.003	
9.0	.127	.066	.024	.109	.057	.021	.076	.040	.015	.044	.024	.009	.014	.008	.003	
10.0	.121	.061	.022	.104	.053	.019	.072	.037	.013	.042	.022	.008	.014	.007	.003	

C Range: 0 - 360DEG
C Interval: 90.0DEG
Test Speed: HIGH
Temperature:25.3DEG
Operators:QUAN
Test Date:2022-12-29

γ Range: 0 - 90DEG
γ Interval: 1.0DEG
Test System:EVERFINE GO-2000B_V1 SYSTEM V2.0.270
Humidity:65.0%
Test Distance:8.140m [K=1.0000]
Remarks:

Uncorrected UGR Table

Test:U:24.00V I:0.5900A P:14.17W PF:1.000 Lamp Flux:1076.53x1 lm		
NAME: HCP-3965143	TYPE:	WEIGHT:
DIM.:	SPEC.:	SERIAL No.:1
MFR.: HAVIT COMMERCIAL	SUR.:0.008	PROTECTION ANGLE:

ceiling/cavity	0.7	0.7	0.5	0.5	0.3	0.7	0.7	0.5	0.5	0.3
walls	0.5	0.3	0.5	0.3	0.3	0.5	0.3	0.5	0.3	0.3
working plane	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2
Room dimensions	Viewed crosswise					Viewed endwise				
x = 2H y = 2H	27.0	28.7	27.3	28.9	29.1	25.7	27.4	26.0	27.6	27.8
3H	29.4	31.0	29.7	31.2	31.5	27.6	29.1	27.9	29.3	29.6
4H	30.5	32.0	30.8	32.2	32.5	28.3	29.8	28.6	30.0	30.3
6H	31.6	33.0	31.9	33.2	33.5	28.8	30.2	29.2	30.5	30.8
8H	32.1	33.4	32.4	33.7	34.0	29.0	30.4	29.4	30.6	31.0
12H	32.6	33.9	33.0	34.2	34.5	29.1	30.4	29.5	30.7	31.0
4H 2H	27.7	29.2	28.0	29.4	29.7	26.8	28.2	27.1	28.5	28.8
3H	30.2	31.5	30.6	31.8	32.2	28.8	30.1	29.1	30.4	30.7
4H	31.5	32.7	31.8	33.0	33.3	29.6	30.8	30.0	31.2	31.5
6H	32.7	33.8	33.1	34.1	34.5	30.3	31.4	30.7	31.7	32.1
8H	33.3	34.3	33.7	34.7	35.1	30.5	31.6	31.0	31.9	32.3
12H	34.0	34.9	34.4	35.3	35.7	30.7	31.6	31.1	32.0	32.4
8H 4H	31.8	32.8	32.2	33.2	33.5	30.2	31.2	30.6	31.6	32.0
6H	33.2	34.1	33.7	34.5	34.9	31.1	32.0	31.6	32.4	32.8
8H	34.0	34.7	34.4	35.2	35.6	31.5	32.3	32.0	32.7	33.1
12H	34.8	35.5	35.3	36.0	36.4	31.8	32.4	32.3	32.9	33.4
12H 4H	31.8	32.7	32.2	33.1	33.5	30.3	31.3	30.8	31.7	32.1
6H	33.3	34.1	33.8	34.5	34.9	31.4	32.1	31.8	32.5	33.0
8H	34.1	34.8	34.6	35.2	35.7	31.8	32.5	32.3	32.9	33.4
Variations with the observer position at spacings:										
S = 1.0H	+ 0.1 / - 0.1					+ 0.1 / - 0.2				
1.5H	+ 0.2 / - 0.2					+ 0.2 / - 0.3				
2.0H	+ 0.2 / - 0.4					+ 0.2 / - 0.5				

CIE Pub.117 Corrected 1077 lm Total Lamp Luminous Flux.(8log(F/F0) = 0.3)

C Range: 0 - 360DEG
C Interval: 90.0DEG
Test Speed: HIGH
Temperature:25.3DEG
Operators:QUAN
Test Date:2022-12-29

γ Range: 0 - 90DEG
γ Interval: 1.0DEG
Test System:EVERFINE GO-2000B_V1 SYSTEM V2.0.270
Humidity:65.0%
Test Distance:8.140m [K=1.0000]
Remarks:

UTILIZATION FACTORS TABLE

Test:U:24.00V I:0.5900A P:14.17W PF:1.000 Lamp Flux:1076.53x1 lm		
NAME: HCP-3965143	TYPE:	WEIGHT:
DIM.:	SPEC.:	SERIAL No.:1
MFR.: HAVIT COMMERCIAL	SUR.:0.008	PROTECTION ANGLE:


REFLECTANCE										
Ceiling	0.8	0.8	0.8	0.7	0.7	0.7	0.5	0.5	0.5	0
Walls	0.7	0.5	0.3	0.7	0.5	0.3	0.7	0.5	0.3	0
Working plane	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0
ROOM INDEX	UTILIZATION FACTORS(PERCENT) k(RI) x RCR = 5									
k = 0.60	53	40	33	52	40	33	51	39	32	25
0.80	62	50	42	61	49	41	59	48	41	33
1.00	71	58	50	69	58	50	67	59	49	41
1.25	78	66	58	76	65	57	73	64	57	49
1.50	83	72	64	81	71	63	78	69	62	54
2.00	91	81	73	89	79	72	85	77	71	62
2.50	95	86	79	93	84	78	89	82	76	67
3.00	99	91	84	96	89	83	92	86	81	72
4.00	103	97	91	101	95	90	96	91	87	77
5.00	106	100	95	104	98	94	99	95	91	81
ROOM INDEX	UF(total)									Direct
According to DIN EN 13032-2 2004				Suspended					SHRNOM = 1.25	

C Range: 0 - 360DEG
C Interval: 90.0DEG
Test Speed: HIGH
Temperature:25.3DEG
Operators:QUAN
Test Date:2022-12-29

γ Range: 0 - 90DEG
γ Interval: 1.0DEG
Test System:EVERFINE GO-2000B_V1 SYSTEM V2.0.270
Humidity:65.0%
Test Distance:8.140m [K=1.0000]
Remarks:

ISOCANDELA DIAGRAM

Test:U:24.00V I:0.5900A P:14.17W PF:1.000 Lamp Flux:1076.53x1 lm		
NAME: HCP-3965143	TYPE:	WEIGHT:
DIM.:	SPEC.:	SERIAL No.:1
MFR.: HAVIT COMMERCIAL	SUR.:0.008	PROTECTION ANGLE:




C Range: 0 - 360DEG
C Interval: 90.0DEG
Test Speed: HIGH
Temperature:25.3DEG
Operators:QUAN
Test Date:2022-12-29

γ Range: 0 - 90DEG
γ Interval: 1.0DEG
Test System:EVERFINE GO-2000B_V1 SYSTEM V2.0.270
Humidity:65.0%
Test Distance:8.140m [K=1.0000]
Remarks:

AAI Figure

Test:U:24.00V I:0.5900A P:14.17W PF:1.000 Lamp Flux:1076.53x1 lm		
NAME: HCP-3965143	TYPE:	WEIGHT:
DIM.:	SPEC.:	SERIAL No.:1
MFR.: HAVIT COMMERCIAL	SUR.:0.008	PROTECTION ANGLE:




Note:The Curves indicate the illuminated area and the average illumination when the luminaire is at different distance.

C Range: 0 - 360DEG
C Interval: 90.0DEG
Test Speed: HIGH
Temperature:25.3DEG
Operators:QUAN
Test Date:2022-12-29

γ Range: 0 - 90DEG
γ Interval: 1.0DEG
Test System:EVERFINE GO-2000B_V1 SYSTEM V2.0.270
Humidity:65.0%
Test Distance:8.140m [K=1.0000]
Remarks:

ISOLUX DIAGRAM


Test:U:24.00V I:0.5900A P:14.17W PF:1.000 Lamp Flux:1076.53x1 lm		
NAME: HCP-3965143	TYPE:	WEIGHT:
DIM.:	SPEC.:	SERIAL No.:1
MFR.: HAVIT COMMERCIAL	SUR.:0.008	PROTECTION ANGLE:



C Range: 0 - 360DEG
C Interval: 90.0DEG
Test Speed: HIGH
Temperature:25.3DEG
Operators:QUAN
Test Date:2022-12-29

γ Range: 0 - 90DEG
γ Interval: 1.0DEG
Test System:EVERFINE GO-2000B_V1 SYSTEM V2.0.270
Humidity:65.0%
Test Distance:8.140m [K=1.0000]
Remarks:

Planar Illuminance Curve



C Range: 0 - 360DEG
C Interval: 90.0DEG
Test Speed: HIGH
Temperature:25.3DEG
Operators:QUAN
Test Date:2022-12-29

γ Range: 0 - 90DEG
γ Interval: 1.0DEG
Test System:EVERFINE GO-2000B_V1 SYSTEM V2.0.270
Humidity:65.0%
Test Distance:8.140m [K=1.0000]
Remarks:

LUMINOUS DISTRIBUTION INTENSITY DATA

Test:U:24.00V I:0.5900A P:14.17W PF:1.000 Lamp Flux:1076.53x1 lm		
NAME: HCP-3965143	TYPE:	WEIGHT:
DIM.:	SPEC.:	SERIAL No.:1
MFR.: HAVIT COMMERCIAL	SUR.:0.008	PROTECTION ANGLE:

Table--1 UNIT: cd

γ (DEG) \ C(DEG)	0	90	180	270
0	282	282	282	282
5	281	282	283	282
10	280	280	283	281
15	277	277	281	277
20	273	272	278	272
25	265	265	272	264
30	256	255	265	255
35	246	244	256	243
40	238	230	248	230
45	229	215	240	214
50	229	197	233	197
55	236	178	239	174
60	229	156	236	149
65	207	133	214	122
70	169	106	175	92.6
75	140	77.1	149	61.8
80	110	47.3	119	31.0
85	81.6	20.1	92.1	4.30
90	57.6	2.86	66.1	0.65

C Range: 0 - 360DEG
C Interval: 90.0DEG
Test Speed: HIGH
Temperature:25.3DEG
Operators:QUAN
Test Date:2022-12-29

γ Range: 0 - 90DEG
γ Interval: 1.0DEG
Test System:EVERFINE GO-2000B_V1 SYSTEM V2.0.270
Humidity:65.0%
Test Distance:8.140m [K=1.0000]
Remarks: