
LUMINAIRE PHOTOMETRIC TEST REPORT

Test:U:24.00V I:0.7590A P:18.30W PF:1.000 Lamp Flux:1342.36x1 lm		
NAME: HCP-3965193	TYPE:	WEIGHT:
DIM.:	SPEC.:	SERIAL No.:1
MFR.: HAVIT COMMERCIAL	SUR.:0.008	PROTECTION ANGLE:


DATA OF LAMP		PHOTOMETRIC DATA		Eff: 73.35 lm/W	
MODEL	3000K	Imax(cd)	349.0	S/MH(C0/180)	1.40
NOMINAL POWER(W)	19.2	LOR(%)	100.0	S/MH(C90/270)	1.34
RATED VOLTAGE(V)	24	TOTAL FLUX(lm)	1342.4	η UP,DN(C0-180)	0.0,50.2
NOMINAL FLUX(lm)	1342.36	CIE CLASS	DIRECT	η UP,DN(C180-360)	0.0,49.8
LAMPS INSIDE	1	η up(%)	0.0	CIBSE SHR NOM	1.50
TEST VOLTAGE(V)	24	η down(%)	100.0	CIBSE SHR MAX	1.55

LUMINOUS INTENSITY DISTRIBUTION DIAGRAM



AVERAGE BEAM ANGLE(50%):138.2 DEG

C0 PLANE ISOLUX DIAGRAM (UNIT:lx)



C Range: 0 - 360DEG
C Interval: 90.0DEG
Test Speed: HIGH
Temperature:25.3DEG
Operators:QUAN
Test Date:2022-12-29

γ Range: 0 - 90DEG
γ Interval: 1.0DEG
Test System:EVERFINE GO-2000B_V1 SYSTEM V2.0.270
Humidity:65.0%
Test Distance:8.140m [K=1.0000]
Remarks:

ZONAL FLUX DIAGRAM

ZONAL FLUX DIAGRAM:

γ	C0	C90	C180	C270					γ	Φ zone	Φ total	%lum,lamp
10	342.9	343.1	348.2	343.0					0- 10	32.93	32.93	2.45,2.45
20	339.2	332.5	342.2	332.1					10- 20	96.59	129.5	9.65,9.65
30	321.1	311.2	328.5	311.4					20- 30	151.6	281.1	20.9,20.9
40	303.2	280.4	303.6	281.1					30- 40	191.6	472.7	35.2,35.2
50	288.4	240.8	278.7	241.9					40- 50	214.3	687.0	51.2,51.2
60	320.9	192.1	302.1	186.4					50- 60	228.5	915.5	68.2,68.2
70	222.9	131.1	245.3	116.5					60- 70	222.6	1138	84.8,84.8
80	128.0	58.61	140.7	38.90					70- 80	141.4	1280	95.3,95.3
90	59.13	3.389	66.54	0.7714					80- 90	62.81	1342	100,100
100									90-100			
110									100-110			
120									110-120			
130									120-130			
140									130-140			
150									140-150			
160									150-160			
170									160-170			
180									170-180			
DEG	LUMINOUS INTENSITY:cd									UNIT:lm		


C Range: 0 - 360DEG
C Interval: 90.0DEG
Test Speed: HIGH
Temperature:25.3DEG
Operators:QUAN
Test Date:2022-12-29

γ Range: 0 - 90DEG
γ Interval: 1.0DEG
Test System:EVERFINE GO-2000B_V1 SYSTEM V2.0.270
Humidity:65.0%
Test Distance:8.140m [K=1.0000]
Remarks:

CU AND LUMINAIRE BUDGETARY ESTIMATE DIAGRAM

Test:U:24.00V I:0.7590A P:18.30W PF:1.000 Lamp Flux:1342.36x1 lm		
NAME: HCP-3965193	TYPE:	WEIGHT:
DIM.:	SPEC.:	SERIAL No.:1
MFR.: HAVIT COMMERCIAL	SUR.:0.008	PROTECTION ANGLE:

ρcc	80%			70%			50%			30%			10%			0
ρw	50%	30%	10%	50%	30%	10%	50%	30%	10%	50%	30%	10%	50%	30%	10%	0
ρfc	20%			20%			20%			20%			20%			0
RCR	RCR:Room Cavity Ratio			Coefficients of Utilization(CU)												
0.0	1.19	1.19	1.19	1.16	1.16	1.16	1.11	1.11	1.11	1.06	1.06	1.06	1.02	1.02	1.02	1.00
1.0	1.01	.96	.91	.98	.94	.89	.94	.90	.87	.90	.87	.84	.86	.84	.81	.79
2.0	.86	.78	.71	.84	.77	.70	.80	.74	.69	.77	.72	.67	.74	.69	.66	.63
3.0	.74	.65	.58	.73	.64	.57	.69	.62	.56	.67	.60	.55	.64	.59	.54	.52
4.0	.65	.55	.48	.63	.54	.47	.61	.53	.47	.58	.51	.46	.56	.50	.45	.43
5.0	.57	.48	.40	.56	.47	.40	.54	.46	.40	.52	.45	.39	.50	.44	.39	.36
6.0	.51	.42	.35	.50	.41	.34	.48	.40	.34	.47	.39	.34	.45	.38	.33	.31
7.0	.46	.37	.30	.45	.36	.30	.44	.36	.30	.42	.35	.30	.41	.34	.29	.27
8.0	.42	.33	.27	.41	.33	.27	.40	.32	.26	.39	.31	.26	.37	.31	.26	.24
9.0	.38	.30	.24	.38	.29	.24	.37	.29	.24	.35	.28	.23	.34	.28	.23	.21
10.0	.35	.27	.21	.35	.27	.21	.34	.26	.21	.33	.26	.21	.32	.26	.21	.19



C Range: 0 - 360DEG
C Interval: 90.0DEG
Test Speed: HIGH
Temperature:25.3DEG
Operators:QUAN
Test Date:2022-12-29

γ Range: 0 - 90DEG
γ Interval: 1.0DEG
Test System:EVERFINE GO-2000B_V1 SYSTEM V2.0.270
Humidity:65.0%
Test Distance:8.140m [K=1.0000]
Remarks:

WEC AND CCEC

Test:U:24.00V I:0.7590A P:18.30W PF:1.000 Lamp Flux:1342.36x1 lm		
NAME: HCP-3965193	TYPE:	WEIGHT:
DIM.:	SPEC.:	SERIAL No.:1
MFR.: HAVIT COMMERCIAL	SUR.:0.008	PROTECTION ANGLE:

ρcc	80%			70%			50%			30%			10%			0
ρw	50%	30%	10%	50%	30%	10%	50%	30%	10%	50%	30%	10%	50%	30%	10%	0
ρfc	20%			20%			20%			20%			20%			0
RCR	RCR:Room Cavity Ratio						Wall Exitance Coeffcients(WEC)									
0.0																
1.0	.371	.211	.067	.363	.207	.066	.350	.201	.064	.337	.194	.062	.326	.189	.061	
2.0	.335	.184	.056	.329	.181	.056	.317	.176	.055	.306	.171	.054	.295	.167	.053	
3.0	.303	.161	.048	.297	.159	.048	.287	.155	.047	.277	.152	.047	.268	.148	.046	
4.0	.275	.143	.042	.270	.141	.042	.260	.138	.041	.252	.135	.041	.243	.132	.040	
5.0	.251	.128	.037	.247	.127	.037	.238	.124	.036	.230	.121	.036	.223	.119	.036	
6.0	.230	.115	.033	.226	.114	.033	.219	.112	.033	.212	.110	.032	.205	.108	.032	
7.0	.213	.105	.030	.209	.104	.030	.202	.102	.029	.196	.100	.029	.190	.099	.029	
8.0	.197	.096	.027	.194	.095	.027	.188	.094	.027	.182	.092	.027	.177	.091	.026	
9.0	.184	.089	.025	.181	.088	.025	.175	.087	.025	.170	.085	.024	.166	.084	.024	
10.0	.172	.082	.023	.169	.082	.023	.164	.081	.023	.160	.079	.023	.156	.078	.022	

ρcc	80%			70%			50%			30%			10%			0
ρw	50%	30%	10%	50%	30%	10%	50%	30%	10%	50%	30%	10%	50%	30%	10%	0
ρfc	20%			20%			20%			20%			20%			0
RCR	RCR:Room Cavity Ratio						Ceiling Cavity Exitance Coefficients(CCEC)									
0.0	.190	.190	.190	.163	.163	.163	.111	.111	.111	.064	.064	.064	.020	.020	.020	
1.0	.185	.156	.130	.158	.134	.112	.108	.092	.077	.062	.053	.045	.020	.017	.015	
2.0	.178	.132	.093	.153	.113	.080	.105	.078	.056	.060	.046	.033	.019	.015	.011	
3.0	.171	.115	.070	.146	.099	.060	.101	.069	.042	.058	.040	.025	.019	.013	.008	
4.0	.163	.102	.054	.140	.088	.047	.096	.061	.033	.056	.036	.020	.018	.012	.006	
5.0	.156	.091	.044	.134	.079	.038	.092	.055	.027	.053	.032	.016	.017	.011	.005	
6.0	.148	.083	.037	.127	.072	.032	.088	.050	.023	.051	.030	.013	.016	.010	.004	
7.0	.141	.076	.031	.121	.066	.027	.084	.046	.019	.049	.027	.012	.016	.009	.004	
8.0	.134	.071	.027	.115	.061	.024	.080	.043	.017	.046	.025	.010	.015	.008	.003	
9.0	.127	.066	.024	.110	.057	.021	.076	.040	.015	.044	.024	.009	.014	.008	.003	
10.0	.121	.061	.022	.104	.053	.019	.072	.037	.013	.042	.022	.008	.014	.007	.003	

C Range: 0 - 360DEG
C Interval: 90.0DEG
Test Speed: HIGH
Temperature:25.3DEG
Operators:QUAN
Test Date:2022-12-29

γ Range: 0 - 90DEG
γ Interval: 1.0DEG
Test System:EVERFINE GO-2000B_V1 SYSTEM V2.0.270
Humidity:65.0%
Test Distance:8.140m [K=1.0000]
Remarks:

Uncorrected UGR Table

Test:U:24.00V I:0.7590A P:18.30W PF:1.000 Lamp Flux:1342.36x1 lm		
NAME: HCP-3965193	TYPE:	WEIGHT:
DIM.:	SPEC.:	SERIAL No.:1
MFR.: HAVIT COMMERCIAL	SUR.:0.008	PROTECTION ANGLE:

ceiling/cavity		0.7	0.7	0.5	0.5	0.3	0.7	0.7	0.5	0.5	0.3
walls		0.5	0.3	0.5	0.3	0.3	0.5	0.3	0.5	0.3	0.3
working plane		0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2
Room dimensions		Viewed crosswise					Viewed endwise				
x = 2H	y = 2H	28.3	30.0	28.6	30.2	30.4	26.6	28.2	26.8	28.4	28.7
	3H	30.7	32.3	31.0	32.5	32.8	28.4	29.9	28.7	30.2	30.4
	4H	31.6	33.1	32.0	33.4	33.6	29.1	30.6	29.4	30.8	31.1
	6H	32.5	33.9	32.8	34.2	34.4	29.6	31.0	30.0	31.3	31.6
	8H	32.9	34.2	33.2	34.5	34.8	29.8	31.1	30.1	31.4	31.7
	12H	33.3	34.6	33.7	34.9	35.2	29.9	31.2	30.2	31.5	31.8
4H	2H	29.0	30.5	29.3	30.7	31.0	27.7	29.2	28.1	29.5	29.7
	3H	31.5	32.8	31.8	33.1	33.4	29.7	31.0	30.0	31.3	31.6
	4H	32.5	33.7	32.9	34.1	34.4	30.5	31.7	30.9	32.0	32.4
	6H	33.5	34.6	33.9	35.0	35.3	31.1	32.2	31.5	32.6	32.9
	8H	34.0	35.1	34.5	35.4	35.8	31.3	32.4	31.8	32.7	33.1
	12H	34.6	35.5	35.0	35.9	36.3	31.5	32.4	31.9	32.8	33.2
8H	4H	32.8	33.8	33.2	34.2	34.5	31.0	32.0	31.4	32.4	32.8
	6H	34.0	34.8	34.4	35.3	35.7	31.9	32.7	32.3	33.1	33.6
	8H	34.6	35.4	35.1	35.8	36.3	32.2	33.0	32.7	33.4	33.9
	12H	35.4	36.0	35.8	36.5	37.0	32.5	33.2	33.0	33.6	34.1
12H	4H	32.8	33.7	33.2	34.1	34.5	31.1	32.1	31.6	32.5	32.9
	6H	34.1	34.8	34.5	35.3	35.7	32.1	32.8	32.5	33.3	33.7
	8H	34.8	35.4	35.3	35.9	36.4	32.5	33.2	33.0	33.6	34.1

Variations with the observer position at spacings:		
S = 1.0H	+ 0.1 / - 0.1	+ 0.1 / - 0.2
1.5H	+ 0.1 / - 0.1	+ 0.2 / - 0.3
2.0H	+ 0.4 / - 0.4	+ 0.3 / - 0.5

CIE Pub.117 Corrected 1342 lm Total Lamp Luminous Flux.(8log(F/F0) = 1.0)

C Range: 0 - 360DEG
C Interval: 90.0DEG
Test Speed: HIGH
Temperature:25.3DEG
Operators:QUAN
Test Date:2022-12-29

γ Range: 0 - 90DEG
γ Interval: 1.0DEG
Test System:EVERFINE GO-2000B_V1 SYSTEM V2.0.270
Humidity:65.0%
Test Distance:8.140m [K=1.0000]
Remarks:

UTILIZATION FACTORS TABLE

Test:U:24.00V I:0.7590A P:18.30W PF:1.000 Lamp Flux:1342.36x1 lm		
NAME: HCP-3965193	TYPE:	WEIGHT:
DIM.:	SPEC.:	SERIAL No.:1
MFR.: HAVIT COMMERCIAL	SUR.:0.008	PROTECTION ANGLE:


REFLECTANCE										
Ceiling	0.8	0.8	0.8	0.7	0.7	0.7	0.5	0.5	0.5	0
Walls	0.7	0.5	0.3	0.7	0.5	0.3	0.7	0.5	0.3	0
Working plane	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0
ROOM INDEX	UTILIZATION FACTORS(PERCENT) k(RI) x RCR = 5									
k = 0.60	53	40	33	52	40	32	51	39	32	25
0.80	62	49	41	61	49	41	59	48	41	33
1.00	70	58	50	69	57	49	67	59	49	41
1.25	78	66	58	76	65	57	73	63	56	48
1.50	83	72	63	81	71	63	78	69	62	53
2.00	90	80	73	88	79	72	85	77	71	62
2.50	95	86	79	93	84	78	89	82	76	67
3.00	99	91	84	96	89	83	92	86	81	72
4.00	103	97	91	101	95	90	96	91	87	78
5.00	106	101	96	104	99	94	99	95	91	81
ROOM INDEX	UF(total)									Direct
According to DIN EN 13032-2 2004				Suspended					SHRNOM = 1.25	

C Range: 0 - 360DEG
C Interval: 90.0DEG
Test Speed: HIGH
Temperature:25.3DEG
Operators:QUAN
Test Date:2022-12-29

γ Range: 0 - 90DEG
γ Interval: 1.0DEG
Test System:EVERFINE GO-2000B_V1 SYSTEM V2.0.270
Humidity:65.0%
Test Distance:8.140m [K=1.0000]
Remarks:

ISOCANDELA DIAGRAM

Test:U:24.00V I:0.7590A P:18.30W PF:1.000 Lamp Flux:1342.36x1 lm		
NAME: HCP-3965193	TYPE:	WEIGHT:
DIM.:	SPEC.:	SERIAL No.:1
MFR.: HAVIT COMMERCIAL	SUR.:0.008	PROTECTION ANGLE:




C Range: 0 - 360DEG
C Interval: 90.0DEG
Test Speed: HIGH
Temperature:25.3DEG
Operators:QUAN
Test Date:2022-12-29

γ Range: 0 - 90DEG
γ Interval: 1.0DEG
Test System:EVERFINE GO-2000B_V1 SYSTEM V2.0.270
Humidity:65.0%
Test Distance:8.140m [K=1.0000]
Remarks:

AAI Figure

Test:U:24.00V I:0.7590A P:18.30W PF:1.000 Lamp Flux:1342.36x1 lm		
NAME: HCP-3965193	TYPE:	WEIGHT:
DIM.:	SPEC.:	SERIAL No.:1
MFR.: HAVIT COMMERCIAL	SUR.:0.008	PROTECTION ANGLE:




Note:The Curves indicate the illuminated area and the average illumination when the luminaire is at different distance.

C Range: 0 - 360DEG
C Interval: 90.0DEG
Test Speed: HIGH
Temperature:25.3DEG
Operators:QUAN
Test Date:2022-12-29

γ Range: 0 - 90DEG
γ Interval: 1.0DEG
Test System:EVERFINE GO-2000B_V1 SYSTEM V2.0.270
Humidity:65.0%
Test Distance:8.140m [K=1.0000]
Remarks:

ISOLUX DIAGRAM


Test:U:24.00V I:0.7590A P:18.30W PF:1.000 Lamp Flux:1342.36x1 lm		
NAME: HCP-3965193	TYPE:	WEIGHT:
DIM.:	SPEC.:	SERIAL No.:1
MFR.: HAVIT COMMERCIAL	SUR.:0.008	PROTECTION ANGLE:



C Range: 0 - 360DEG
C Interval: 90.0DEG
Test Speed: HIGH
Temperature:25.3DEG
Operators:QUAN
Test Date:2022-12-29

γ Range: 0 - 90DEG
γ Interval: 1.0DEG
Test System:EVERFINE GO-2000B_V1 SYSTEM V2.0.270
Humidity:65.0%
Test Distance:8.140m [K=1.0000]
Remarks:

Planar Illuminance Curve



C Range: 0 - 360DEG
C Interval: 90.0DEG
Test Speed: HIGH
Temperature:25.3DEG
Operators:QUAN
Test Date:2022-12-29

γ Range: 0 - 90DEG
γ Interval: 1.0DEG
Test System:EVERFINE GO-2000B_V1 SYSTEM V2.0.270
Humidity:65.0%
Test Distance:8.140m [K=1.0000]
Remarks:

LUMINOUS DISTRIBUTION INTENSITY DATA

Test:U:24.00V I:0.7590A P:18.30W PF:1.000 Lamp Flux:1342.36x1 lm		
NAME: HCP-3965193	TYPE:	WEIGHT:
DIM.:	SPEC.:	SERIAL No.:1
MFR.: HAVIT COMMERCIAL	SUR.:0.008	PROTECTION ANGLE:

Table--1 UNIT: cd

γ (DEG) \ C(DEG)	0	90	180	270
0	345	345	345	345
5	343	345	349	345
10	343	343	348	343
15	342	339	346	339
20	339	333	342	332
25	332	323	336	323
30	321	311	328	311
35	312	297	317	297
40	303	280	304	281
45	295	262	289	263
50	288	241	279	242
55	300	218	280	216
60	321	192	302	186
65	297	163	307	153
70	223	131	245	116
75	169	95.5	191	77.5
80	128	58.6	141	38.9
85	88.8	24.9	101	5.36
90	59.1	3.39	66.5	0.77

C Range: 0 - 360DEG
C Interval: 90.0DEG
Test Speed: HIGH
Temperature:25.3DEG
Operators:QUAN
Test Date:2022-12-29

γ Range: 0 - 90DEG
γ Interval: 1.0DEG
Test System:EVERFINE GO-2000B_V1 SYSTEM V2.0.270
Humidity:65.0%
Test Distance:8.140m [K=1.0000]
Remarks: