

Indoor Luminaire Photometric Data


Description Information

Luminary Name: HCP-809024-3000K RA90 40D	Lum. Catalog:	Test ID: 01
Lamp Name:	Lamp Catalog: LED	Test Date: 2020/09/22
Manufacture: Havit Commercial	Shld. Ang(°):	Test Machine: GON-2000
Test Lab: Quality Department	Frequency (Hz):	Lamp CCT (K): Ra:
Lum. Size (W*L*H): 0.050m*0.000m*0.080m	Lum. Area (m2): 0.016	Lum. W (kg): 0.000
Test System: C, γ	Test Step: C=90.0 γ=1.0	Temp. (°C): 25
		Humidity (%): 50.0


Character Parameter

Lamp Speciality Parameter	Luminaire Speciality Parameter	
Rated Flux(lm): 546.050	Luminary Flux(lm): 546.050	Field Angle(10%Imax): 86.2(°)
Rated Power(W):	Luminary Efficiency: 100.00%	Down Lumens&Percent: 543.106lm 99.46%
Rated Voltage(V):	Luminary EER(lm/W): 62.728	Up Lumens&Percent: 2.944lm 0.54%
Tested Power(W): 8.705	Max. Candela(cd): 834.868	S/MH: C0_a180=0.624 C90_270=0.618
Lamps' Inside: 1	Max Cand@Ang. (°): C=0.0 γ=1.0	CIE Type: Semi-Direct
Tested Electrics (V, A, pf): 240.4, 0.039, 0.908	Beam Angle(50%Imax): 40.2(°)	ErP Φ use(90°): 503.260lm
Lamp Size (W*L*H): 0.050m*0.000m*0.080m	Left=-19.6°, Right=20.6°	IRF (%): 326.367

C Plane Distribution Diagram





C0 Space ISO Illuminance Curve



2D Plane Light Intensity Distribution Curve

Lum. Name: HCP-809024-3000K RA90 40D	Lum. Catalog:	Test ID: 01
Lamp Name:	Lamp Catalog: LED	Test Lab: Quality Department
Manufacture: Havit Commercial	Test Machine: GON-2000	Test Date: 2020/09/22

C Plane Distribution Diagram




C Plane	[50%MaxAng.]	[10%MaxAng.]
C0.0_180.0 :	40.2	86.2
C90.0_270.0 :	40.1	86.5

Unit:cd

3D Light Intensity Distribution Modal

Lum. Name: HCP-809024-3000K RA90 40D	Lum. Catalog:	Test ID: 01
Lamp Name:	Lamp Catalog: LED	Test Lab: Quality Department
Manufacture: Havit Commercial	Test Machine: GON-2000	Test Date: 2020/09/22

3D Light Intensity Distribution Modal



Curves: 3D Model — Fixture — Vert. HUD — Hori. HUD —
View Angles: Orient:0 Tilt:0 Roll:0 Spin:0

Zonal Flux Tabulation

Zone(γ)	Zone Flux (lm)	Sums Flux (lm)	Zone%Lamp	Sums%Lamp	Zone(γ)	Zone Flux (lm)	Sums Flux (lm)	Zone%Lamp	Sums%Lamp
0.0-1.0	0.79	0.79	0.14	0.14	47.0-48.0	2.18	515.63	0.40	94.43
1.0-2.0	2.36	3.15	0.43	0.58	48.0-49.0	1.91	517.54	0.35	94.78
2.0-3.0	3.89	7.04	0.71	1.29	49.0-50.0	1.77	519.30	0.32	95.10
3.0-4.0	5.37	12.41	0.98	2.27	50.0-51.0	1.66	520.96	0.30	95.41
4.0-5.0	6.77	19.18	1.24	3.51	51.0-52.0	1.55	522.51	0.28	95.69
5.0-6.0	8.05	27.24	1.47	4.99	52.0-53.0	1.44	523.95	0.26	95.95
6.0-7.0	9.20	36.44	1.68	6.67	53.0-54.0	1.35	525.31	0.25	96.20
7.0-8.0	10.21	46.64	1.87	8.54	54.0-55.0	1.28	526.59	0.24	96.44
8.0-9.0	11.08	57.73	2.03	10.57	55.0-56.0	1.22	527.81	0.22	96.66
9.0-10.0	11.84	69.57	2.17	12.74	56.0-57.0	1.15	528.96	0.21	96.87
10.0-11.0	12.51	82.08	2.29	15.03	57.0-58.0	1.09	530.05	0.20	97.07
11.0-12.0	13.12	95.20	2.40	17.43	58.0-59.0	1.02	531.07	0.19	97.26
12.0-13.0	13.68	108.87	2.50	19.94	59.0-60.0	0.96	532.03	0.18	97.43
13.0-14.0	14.18	123.05	2.60	22.54	60.0-61.0	0.91	532.94	0.17	97.60
14.0-15.0	14.61	137.66	2.68	25.21	61.0-62.0	0.85	533.79	0.16	97.75
15.0-16.0	14.98	152.64	2.74	27.95	62.0-63.0	0.79	534.57	0.14	97.90
16.0-17.0	15.27	167.91	2.80	30.75	63.0-64.0	0.72	535.30	0.13	98.03
17.0-18.0	15.49	183.40	2.84	33.59	64.0-65.0	0.67	535.96	0.12	98.15
18.0-19.0	15.62	199.02	2.86	36.45	65.0-66.0	0.61	536.57	0.11	98.26
19.0-20.0	15.65	214.68	2.87	39.31	66.0-67.0	0.55	537.13	0.10	98.37
20.0-21.0	15.60	230.28	2.86	42.17	67.0-68.0	0.51	537.63	0.09	98.46
21.0-22.0	15.47	245.75	2.83	45.01	68.0-69.0	0.47	538.11	0.09	98.55
22.0-23.0	15.27	261.02	2.80	47.80	69.0-70.0	0.44	538.54	0.08	98.63
23.0-24.0	14.99	276.02	2.75	50.55	70.0-71.0	0.41	538.96	0.08	98.70
24.0-25.0	14.66	290.68	2.68	53.23	71.0-72.0	0.39	539.34	0.07	98.77
25.0-26.0	14.28	304.95	2.61	55.85	72.0-73.0	0.36	539.70	0.07	98.84
26.0-27.0	13.86	318.81	2.54	58.38	73.0-74.0	0.34	540.04	0.06	98.90
27.0-28.0	13.41	332.22	2.46	60.84	74.0-75.0	0.32	540.36	0.06	98.96
28.0-29.0	13.00	345.22	2.38	63.22	75.0-76.0	0.30	540.66	0.06	99.01
29.0-30.0	12.65	357.87	2.32	65.54	76.0-77.0	0.28	540.95	0.05	99.07
30.0-31.0	12.37	370.24	2.26	67.80	77.0-78.0	0.27	541.21	0.05	99.11
31.0-32.0	12.12	382.36	2.22	70.02	78.0-79.0	0.25	541.46	0.05	99.16
32.0-33.0	11.91	394.27	2.18	72.20	79.0-80.0	0.23	541.70	0.04	99.20
33.0-34.0	11.74	406.01	2.15	74.35	80.0-81.0	0.22	541.92	0.04	99.24
34.0-35.0	11.57	417.58	2.12	76.47	81.0-82.0	0.20	542.12	0.04	99.28
35.0-36.0	11.42	429.00	2.09	78.56	82.0-83.0	0.19	542.31	0.03	99.31
36.0-37.0	11.28	440.28	2.07	80.63	83.0-84.0	0.17	542.48	0.03	99.35
37.0-38.0	11.09	451.38	2.03	82.66	84.0-85.0	0.16	542.64	0.03	99.37
38.0-39.0	10.72	462.09	1.96	84.62	85.0-86.0	0.14	542.78	0.03	99.40
39.0-40.0	10.08	472.17	1.85	86.47	86.0-87.0	0.12	542.90	0.02	99.42
40.0-41.0	9.22	481.40	1.69	88.16	87.0-88.0	0.10	542.99	0.02	99.44
41.0-42.0	8.19	489.59	1.50	89.66	88.0-89.0	0.07	543.06	0.01	99.45
42.0-43.0	7.06	496.65	1.29	90.95	89.0-90.0	0.05	543.11	0.01	99.46
43.0-44.0	5.86	502.51	1.07	92.03	90.0-91.0	0.03	543.14	0.01	99.47
44.0-45.0	4.66	507.17	0.85	92.88	91.0-92.0	0.03	543.17	0.01	99.47
45.0-46.0	3.56	510.73	0.65	93.53	92.0-93.0	0.02	543.19	0.00	99.48
46.0-47.0	2.71	513.44	0.50	94.03	93.0-94.0	0.02	543.22	0.00	99.48


Zonal Flux Tabulation - (Cont.)

Zone (γ)	Zone Flux (lm)	Sums Flux (lm)	Zone%Lamp	Sums%Lamp	Zone (γ)	Zone Flux (lm)	Sums Flux (lm)	Zone%Lamp	Sums%Lamp
94.0-95.0	0.02	543.23	0.00	99.48	141.0-142.0	0.06	543.85	0.01	99.60
95.0-96.0	0.02	543.25	0.00	99.49	142.0-143.0	0.07	543.92	0.01	99.61
96.0-97.0	0.01	543.26	0.00	99.49	143.0-144.0	0.07	543.99	0.01	99.62
97.0-98.0	0.01	543.27	0.00	99.49	144.0-145.0	0.07	544.06	0.01	99.63
98.0-99.0	0.01	543.28	0.00	99.49	145.0-146.0	0.07	544.13	0.01	99.65
99.0-100.0	0.01	543.28	0.00	99.49	146.0-147.0	0.07	544.20	0.01	99.66
100.0-101.0	0.00	543.29	0.00	99.49	147.0-148.0	0.08	544.28	0.01	99.68
101.0-102.0	0.00	543.29	0.00	99.49	148.0-149.0	0.08	544.36	0.01	99.69
102.0-103.0	0.00	543.29	0.00	99.49	149.0-150.0	0.08	544.44	0.01	99.70
103.0-104.0	0.00	543.29	0.00	99.49	150.0-151.0	0.08	544.52	0.01	99.72
104.0-105.0	0.00	543.29	0.00	99.49	151.0-152.0	0.08	544.59	0.01	99.73
105.0-106.0	0.00	543.29	0.00	99.49	152.0-153.0	0.08	544.67	0.01	99.75
106.0-107.0	0.00	543.29	0.00	99.49	153.0-154.0	0.08	544.75	0.01	99.76
107.0-108.0	0.00	543.29	0.00	99.49	154.0-155.0	0.08	544.83	0.01	99.78
108.0-109.0	0.00	543.29	0.00	99.49	155.0-156.0	0.08	544.91	0.01	99.79
109.0-110.0	0.00	543.29	0.00	99.49	156.0-157.0	0.08	544.99	0.01	99.81
110.0-111.0	0.00	543.29	0.00	99.49	157.0-158.0	0.08	545.07	0.01	99.82
111.0-112.0	0.00	543.29	0.00	99.49	158.0-159.0	0.08	545.14	0.01	99.83
112.0-113.0	0.00	543.29	0.00	99.49	159.0-160.0	0.07	545.22	0.01	99.85
113.0-114.0	0.00	543.29	0.00	99.49	160.0-161.0	0.07	545.29	0.01	99.86
114.0-115.0	0.00	543.29	0.00	99.49	161.0-162.0	0.07	545.36	0.01	99.87
115.0-116.0	0.00	543.29	0.00	99.49	162.0-163.0	0.07	545.43	0.01	99.89
116.0-117.0	0.00	543.29	0.00	99.49	163.0-164.0	0.07	545.49	0.01	99.90
117.0-118.0	0.00	543.29	0.00	99.49	164.0-165.0	0.06	545.56	0.01	99.91
118.0-119.0	0.00	543.29	0.00	99.49	165.0-166.0	0.06	545.61	0.01	99.92
119.0-120.0	0.00	543.29	0.00	99.49	166.0-167.0	0.06	545.67	0.01	99.93
120.0-121.0	0.00	543.29	0.00	99.49	167.0-168.0	0.05	545.72	0.01	99.94
121.0-122.0	0.00	543.29	0.00	99.49	168.0-169.0	0.05	545.77	0.01	99.95
122.0-123.0	0.00	543.29	0.00	99.50	169.0-170.0	0.05	545.82	0.01	99.96
123.0-124.0	0.00	543.29	0.00	99.50	170.0-171.0	0.04	545.86	0.01	99.97
124.0-125.0	0.00	543.30	0.00	99.50	171.0-172.0	0.04	545.90	0.01	99.97
125.0-126.0	0.00	543.30	0.00	99.50	172.0-173.0	0.03	545.94	0.01	99.98
126.0-127.0	0.01	543.31	0.00	99.50	173.0-174.0	0.03	545.97	0.01	99.98
127.0-128.0	0.01	543.32	0.00	99.50	174.0-175.0	0.03	545.99	0.00	99.99
128.0-129.0	0.01	543.33	0.00	99.50	175.0-176.0	0.02	546.01	0.00	99.99
129.0-130.0	0.02	543.35	0.00	99.51	176.0-177.0	0.02	546.03	0.00	100.00
130.0-131.0	0.02	543.37	0.00	99.51	177.0-178.0	0.01	546.04	0.00	100.00
131.0-132.0	0.02	543.39	0.00	99.51	178.0-179.0	0.01	546.05	0.00	100.00
132.0-133.0	0.03	543.42	0.01	99.52	179.0-180.0	0.00	546.05	0.00	100.00
133.0-134.0	0.03	543.45	0.01	99.52					
134.0-135.0	0.04	543.49	0.01	99.53					
135.0-136.0	0.04	543.53	0.01	99.54					
136.0-137.0	0.04	543.57	0.01	99.55					
137.0-138.0	0.05	543.62	0.01	99.56					
138.0-139.0	0.05	543.67	0.01	99.56					
139.0-140.0	0.06	543.73	0.01	99.57					
140.0-141.0	0.06	543.79	0.01	99.59					

Rectangle ISO Lighting Intensity Diagram

Lum. Name: HCP-809024-3000K RA90 40D	Lum. Catalog:	Test ID: 01
Lamp Name:	Lamp Catalog: LED	Test Lab: Quality Department
Manufacture: Havit Commercial	Test Machine: GON-2000	Test Date: 2020/09/22

ISO Lighting Intensity Curve




Maximum Light Intensity(cd): 834.87

Maximum Cand.@Angle: H=1.0°,V=0.0°

Plane ISO-Illuminance Diagram

Lum. Name: HCP-809024-3000K RA90 40D	Lum. Catalog:	Test ID: 01
Lamp Name:	Lamp Catalog: LED	Test Lab: Quality Department
Manufacture: Havit Commercial	Test Machine: GON-2000	Test Date: 2020/09/22

Plane ISO-Illuminance Curve



Working Plane Luminaire Mounting Height(m): 3.00


Working Plane Maximum Illuminance(lx): 92.72

Working Plane Maximum Illuminance Position(d/h): H0.0 V0.0

3D Plane ISO Illuminance Diagram

Lum. Name: HCP-809024-3000K RA90 40D	Lum. Catalog:	Test ID: 01
Lamp Name:	Lamp Catalog: LED	Test Lab: Quality Department
Manufacture: Havit Commercial	Test Machine: GON-2000	Test Date: 2020/09/22

3D Plane Illuminance Modal




Curves: 3D Model — 90% — 80% — 70% — 60% — 50% — 40% — 30% — 20% — 10% —
View Angles(deg): 0 Height(m): 3.0 Distance(m): 10.0

Space ISO Illuminance Diagram

Lum. Name: HCP-809024-3000K RA90 40D	Lum. Catalog:	Test ID: 01
Lamp Name:	Lamp Catalog: LED	Test Lab: Quality Department
Manufacture: Havit Commercial	Test Machine: GON-2000	Test Date: 2020/09/22

Space ISO Illuminance Curve



Curves:

[Unit: lx]

[E_{Max}] =834.487

— [E_{Max}*90%]=751.038

— [E_{Max}*80%]=667.589

— [E_{Max}*70%]=584.141

— [E_{Max}*60%]=500.692

— [E_{Max}*50%]=417.243

— [E_{Max}*40%]=333.795

— [E_{Max}*30%]=250.346

— [E_{Max}*20%]=166.897

— [E_{Max}*10%]=83.449


Space Plane Maximum Illuminance and @Angle:834.49lx,1.0deg

Plane Maximum Lighting Intensity and @Angle:834.868cd,0deg

Illuminance-Distance Diagram

Lum. Name: HCP-809024-3000K RA90 40D	Lum. Catalog:	Test ID: 01
Lamp Name:	Lamp Catalog: LED	Test Lab: Quality Department
Manufacture: Havit Commercial	Test Machine: GON-2000	Test Date: 2020/09/22

Illuminance-Distance Curve



Indoor Luminance Limiting Curves

Lum. Name: HCP-809024-3000K RA90 40D	Lum. Catalog:	Test ID: 01
Lamp Name:	Lamp Catalog: LED	Test Lab: Quality Department
Manufacture: Havit Commercial	Test Machine: GON-2000	Test Date: 2020/09/22


Glare Grade Table

GI	Quality	Using Illuminance							
1.15	A	2000	1000	500	<=300				
1.5	B		2000	1000	500	<=300			
1.85	C			2000	1000	500	<=300		
2.2	D				2000	1000	500	<=300	
2.55	E	a				2000	1000	500	<=300
			b	c	d	e	f	g	h

Luminance Table

Gama(deg)	45	50	55	60	65	70	75	80	85
C0	5399	2233	1771	1459	1164	912	833	874	1161
C90	4569	1974	1495	1201	917	702	634	642	754

Luminance Limiting Curve




Luminous Size: Length(m)=0.000 Width(m)=-0.050 Height(m)=0.080 Area(m^2)=0.015708

Luminous Type: Without Luminous Side

Luminous Curves: C0-C180 Color: — C90-C270 Color: —

Indoor Budgetary Estimate Table

Lum. Name: HCP-809024-3000K RA90 40D	Lum. Catalog:	Test ID: 01
Lamp Name:	Lamp Catalog: LED	Test Lab: Quality Department
Manufacture: Havit Commercial	Test Machine: GON-2000	Test Date: 2020/09/22



Parameters1: Rhocc = 0.7 Rhow = 0.5 Rhofc = 0.2 LLF = 0.8
Parameters2: Rhocc = 0.5 Rhow = 0.3 Rhofc = 0.2 LLF = 0.8
Average Illuminance(lx): 100 Cavity Height: H1(m) = 2

Indoor Coefficient of Utilization Table

Lum. Name: HCP-809024-3000K RA90 40D	Lum. Catalog:	Test ID: 01
Lamp Name:	Lamp Catalog: LED	Test Lab: Quality Department
Manufacture: Havit Commercial	Test Machine: GON-2000	Test Date: 2020/09/22

Coefficients of Utilization – Zonal Cavity Method																		
Coef.	Effective Floor Cavity Reflectance RFC=0.20																	
RhoCC (%)	80				70				50			30			10			0
RhoW (%)	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	0
RCR	Coefficient of Utilization (%)																	
0	119	119	119	119	116	116	116	116	111	111	111	106	106	106	102	102	102	99
1	113	110	107	105	110	108	106	103	104	102	100	100	98	97	96	95	94	92
2	107	102	98	94	105	100	96	93	97	94	91	94	91	89	91	89	87	85
3	101	95	90	85	99	93	89	85	91	87	83	88	85	82	86	83	81	79
4	96	88	83	78	94	87	82	78	85	80	77	83	79	76	81	78	75	73
5	91	83	77	72	89	82	76	72	80	75	71	78	74	70	76	73	70	68
6	87	77	71	67	85	77	71	67	75	70	66	73	69	66	72	68	65	64
7	82	73	67	62	81	72	66	62	71	65	62	69	65	61	68	64	61	59
8	78	69	62	58	77	68	62	58	67	62	58	66	61	57	65	60	57	56
9	75	65	59	55	73	64	58	55	63	58	54	62	58	54	61	57	54	53
10	71	61	55	51	70	61	55	51	60	55	51	59	54	51	58	54	51	50

Unified Glare Rating Table

Lum. Name: HCP-809024-3000K RA90 40D	Lum. Catalog:	Test ID: 01
Lamp Name:	Lamp Catalog: LED	Test Lab: Quality Department
Manufacture: Havit Commercial	Test Machine: GON-2000	Test Date: 2020/09/22

Unified Glare Rating Table

Ceiling RCC	0.70	0.70	0.50	0.50	0.30	0.70	0.70	0.50	0.50	0.30
Wall RW	0.50	0.30	0.50	0.30	0.30	0.50	0.30	0.50	0.30	0.30
Floor RFC	0.20	0.20	0.20	0.20	0.20	0.20	0.20	0.20	0.20	0.20
Room Size	Vewed crosswise					Vewed endwise				
X=2H Y=2H	14.6	15.7	15.0	16.0	16.3	14.1	15.1	14.5	15.5	15.8
	14.6	15.5	15.0	15.9	16.2	14.0	14.9	14.4	15.3	15.7
	14.6	15.4	15.0	15.8	16.2	14.0	14.8	14.4	15.2	15.6
	14.5	15.3	15.0	15.7	16.1	13.9	14.7	14.3	15.1	15.5
	14.5	15.3	15.0	15.7	16.1	13.9	14.6	14.3	15.0	15.5
	14.5	15.2	15.0	15.6	16.1	13.9	14.6	14.3	15.0	15.4
X=4H Y=2H	14.4	15.3	14.9	15.7	16.1	13.9	14.8	14.3	15.1	15.5
	14.4	15.1	14.9	15.6	16.0	13.9	14.6	14.3	15.0	15.4
	14.4	15.1	14.9	15.5	16.0	13.8	14.5	14.3	14.9	15.3
	14.5	15.0	14.9	15.5	15.9	13.8	14.4	14.3	14.8	15.3
	14.5	15.0	14.9	15.4	15.9	13.8	14.3	14.3	14.8	15.2
	14.5	14.9	15.0	15.4	15.9	13.8	14.2	14.3	14.7	15.2
X=8H Y=4H	14.3	14.8	14.8	15.3	15.8	13.7	14.2	14.2	14.7	15.2
	14.4	14.8	14.9	15.3	15.8	13.7	14.1	14.2	14.6	15.2
	14.4	14.8	15.0	15.3	15.8	13.7	14.1	14.3	14.6	15.1
	14.5	14.8	15.0	15.3	15.9	13.8	14.1	14.3	14.6	15.2
X=12H Y=4H	14.3	14.7	14.8	15.2	15.7	13.7	14.1	14.2	14.6	15.1
	14.3	14.7	14.9	15.2	15.7	13.7	14.0	14.2	14.5	15.1
	14.4	14.7	14.9	15.2	15.8	13.7	14.0	14.2	14.5	15.1
Variations with the observer position at spacings										
S=1.0H	0.2/−0.2					0.4/−0.4				
S=1.5H	0.5/−0.6					0.6/−0.7				
S=2.0H	1.1/−0.9					1.3/−1.1				
Reduced UGR Table:										
Nordic Standard Table:	BK0					BK0				
Correction Value	0.5					0.4				

o the CIE Pub.117, data has been corrected, refers to the lamp's lumens 8.2flm.

Candela Tabulation

V/H	C0.0	C90.0	C180.0	C270.0
γ 0.0	826.70	826.70	826.70	826.70
γ 1.0	834.87	817.94	820.99	819.75
γ 2.0	834.13	813.40	810.69	815.57
γ 3.0	826.86	804.59	797.92	806.90
γ 4.0	814.36	792.91	781.81	795.10
γ 5.0	797.43	774.78	762.56	777.55
γ 6.0	776.40	750.70	736.69	754.13
γ 7.0	751.81	723.13	705.75	729.17
γ 8.0	723.91	695.36	674.20	701.99
γ 9.0	693.23	665.56	643.78	672.63
γ 10.0	662.07	637.28	616.73	642.77
γ 11.0	632.13	610.34	592.69	613.51
γ 12.0	606.64	585.41	570.93	588.63
γ 13.0	582.22	561.28	550.24	564.97
γ 14.0	558.74	539.43	531.43	542.23
γ 15.0	536.62	518.12	511.12	519.46
γ 16.0	514.43	498.26	491.51	499.28
γ 17.0	492.75	476.27	471.36	479.08
γ 18.0	472.45	454.55	451.63	459.45
γ 19.0	451.55	432.78	430.41	438.46
γ 20.0	430.21	411.73	408.50	417.22
γ 21.0	409.25	390.75	386.29	396.10
γ 22.0	387.73	370.13	364.36	375.53
γ 23.0	366.53	349.90	342.04	354.79
γ 24.0	345.32	329.91	319.83	335.01
γ 25.0	324.71	310.52	299.18	314.31
γ 26.0	304.79	291.46	279.20	295.24
γ 27.0	286.16	271.92	260.42	276.06
γ 28.0	267.96	255.21	243.20	258.30
γ 29.0	251.24	239.41	229.62	242.56
γ 30.0	237.10	226.93	218.16	229.41
γ 31.0	224.49	216.57	207.17	217.58
γ 32.0	215.12	205.82	198.19	207.41
γ 33.0	204.99	197.53	190.54	197.92
γ 34.0	196.55	190.77	183.26	189.67
γ 35.0	189.18	182.56	176.19	182.21
γ 36.0	182.10	176.37	169.70	176.20
γ 37.0	175.16	170.34	163.31	170.58
γ 38.0	168.75	161.58	155.66	163.96
γ 39.0	160.56	148.80	143.72	153.13
γ 40.0	149.29	133.45	127.92	139.27
γ 41.0	134.28	117.57	110.53	123.53
γ 42.0	116.03	100.63	92.26	107.28
γ 43.0	97.34	83.82	73.97	90.64
γ 44.0	78.42	67.04	56.59	73.65
γ 45.0	59.96	50.75	41.13	57.33
γ 46.0	44.78	36.83	30.82	42.63

Candela Tabulation - (Cont.)

V/H	C0.0	C90.0	C180.0	C270.0
γ 47.0	33.47	27.51	24.94	32.03
γ 48.0	27.58	23.21	22.06	25.15
γ 49.0	24.30	21.33	20.22	22.13
γ 50.0	22.54	19.93	18.32	20.77
γ 51.0	21.17	18.35	16.62	19.38
γ 52.0	19.64	16.65	15.02	17.55
γ 53.0	18.16	15.42	13.79	16.07
γ 54.0	17.02	14.47	12.92	15.10
γ 55.0	15.95	13.47	12.01	14.11
γ 56.0	14.96	12.60	11.28	13.23
γ 57.0	14.01	11.77	10.52	12.34
γ 58.0	13.17	10.97	9.76	11.60
γ 59.0	12.29	10.14	9.00	10.70
γ 60.0	11.46	9.44	8.39	9.98
γ 61.0	10.74	8.79	7.74	9.33
γ 62.0	10.02	8.15	7.11	8.63
γ 63.0	9.27	7.35	6.36	7.90
γ 64.0	8.41	6.71	5.78	7.22
γ 65.0	7.73	6.09	5.26	6.60
γ 66.0	7.04	5.43	4.67	5.99
γ 67.0	6.29	4.90	4.28	5.41
γ 68.0	5.77	4.48	3.98	5.00
γ 69.0	5.30	4.10	3.71	4.64
γ 70.0	4.90	3.77	3.47	4.33
γ 71.0	4.51	3.49	3.27	4.05
γ 72.0	4.19	3.23	3.08	3.81
γ 73.0	3.89	3.00	2.90	3.59
γ 74.0	3.63	2.78	2.73	3.38
γ 75.0	3.39	2.58	2.56	3.18
γ 76.0	3.15	2.42	2.43	3.01
γ 77.0	2.94	2.23	2.30	2.82
γ 78.0	2.74	2.07	2.16	2.65
γ 79.0	2.56	1.91	2.02	2.48
γ 80.0	2.38	1.75	1.90	2.31
γ 81.0	2.21	1.59	1.76	2.18
γ 82.0	2.05	1.45	1.64	2.04
γ 83.0	1.89	1.32	1.52	1.91
γ 84.0	1.73	1.18	1.38	1.76
γ 85.0	1.59	1.03	1.23	1.57
γ 86.0	1.43	0.88	1.09	1.43
γ 87.0	1.26	0.73	0.84	1.24
γ 88.0	1.07	0.43	0.50	1.00
γ 89.0	0.81	0.14	0.19	0.76
γ 90.0	0.60	0.04	0.12	0.64
γ 91.0	0.52	0.00	0.07	0.56
γ 92.0	0.45	0.00	0.02	0.49
γ 93.0	0.39	0.00	0.00	0.43

Candela Tabulation - (Cont.)

V/H	C0.0	C90.0	C180.0	C270.0
γ 94.0	0.33	0.00	0.00	0.38
γ 95.0	0.28	0.00	0.00	0.32
γ 96.0	0.23	0.00	0.00	0.27
γ 97.0	0.18	0.00	0.00	0.23
γ 98.0	0.14	0.00	0.00	0.18
γ 99.0	0.10	0.00	0.00	0.13
γ 100.0	0.06	0.00	0.00	0.10
γ 101.0	0.02	0.00	0.00	0.07
γ 102.0	0.00	0.00	0.00	0.05
γ 103.0	0.00	0.00	0.00	0.01
γ 104.0	0.00	0.00	0.00	0.00
γ 105.0	0.00	0.00	0.00	0.00
γ 106.0	0.00	0.00	0.00	0.00
γ 107.0	0.00	0.00	0.00	0.00
γ 108.0	0.00	0.00	0.00	0.00
γ 109.0	0.00	0.00	0.00	0.00
γ 110.0	0.00	0.00	0.00	0.00
γ 111.0	0.00	0.00	0.00	0.00
γ 112.0	0.00	0.00	0.00	0.00
γ 113.0	0.00	0.00	0.00	0.00
γ 114.0	0.00	0.00	0.00	0.00
γ 115.0	0.00	0.00	0.00	0.00
γ 116.0	0.00	0.00	0.00	0.00
γ 117.0	0.00	0.00	0.00	0.00
γ 118.0	0.00	0.00	0.00	0.00
γ 119.0	0.00	0.00	0.00	0.00
γ 120.0	0.00	0.00	0.00	0.00
γ 121.0	0.00	0.00	0.00	0.02
γ 122.0	0.00	0.00	0.00	0.04
γ 123.0	0.00	0.00	0.00	0.08
γ 124.0	0.00	0.00	0.00	0.12
γ 125.0	0.00	0.00	0.00	0.15
γ 126.0	0.03	0.00	0.05	0.19
γ 127.0	0.07	0.00	0.11	0.21
γ 128.0	0.11	0.00	0.16	0.26
γ 129.0	0.15	0.00	0.21	0.30
γ 130.0	0.21	0.05	0.25	0.34
γ 131.0	0.25	0.11	0.31	0.40
γ 132.0	0.29	0.16	0.36	0.44
γ 133.0	0.36	0.22	0.41	0.50
γ 134.0	0.41	0.28	0.49	0.56
γ 135.0	0.46	0.34	0.56	0.61
γ 136.0	0.52	0.40	0.63	0.67
γ 137.0	0.57	0.47	0.69	0.74
γ 138.0	0.65	0.53	0.76	0.80
γ 139.0	0.71	0.60	0.82	0.87
γ 140.0	0.77	0.67	0.90	0.93

Candela Tabulation - (Cont.)

V/H	C0.0	C90.0	C180.0	C270.0
γ 141.0	0.84	0.75	0.97	1.00
γ 142.0	0.90	0.81	1.04	1.06
γ 143.0	0.97	0.87	1.11	1.12
γ 144.0	1.03	0.94	1.17	1.19
γ 145.0	1.09	1.00	1.23	1.24
γ 146.0	1.16	1.07	1.30	1.30
γ 147.0	1.21	1.12	1.36	1.36
γ 148.0	1.28	1.19	1.42	1.42
γ 149.0	1.34	1.25	1.47	1.46
γ 150.0	1.39	1.31	1.53	1.52
γ 151.0	1.45	1.36	1.58	1.56
γ 152.0	1.51	1.43	1.62	1.61
γ 153.0	1.57	1.48	1.69	1.67
γ 154.0	1.63	1.54	1.74	1.71
γ 155.0	1.68	1.58	1.79	1.76
γ 156.0	1.74	1.64	1.85	1.81
γ 157.0	1.80	1.70	1.89	1.86
γ 158.0	1.85	1.74	1.94	1.91
γ 159.0	1.91	1.79	2.00	1.94
γ 160.0	1.95	1.84	2.04	1.99
γ 161.0	1.99	1.89	2.08	2.03
γ 162.0	2.04	1.93	2.12	2.07
γ 163.0	2.09	1.97	2.16	2.10
γ 164.0	2.13	2.02	2.18	2.13
γ 165.0	2.17	2.05	2.21	2.16
γ 166.0	2.20	2.10	2.25	2.20
γ 167.0	2.25	2.14	2.28	2.23
γ 168.0	2.27	2.18	2.32	2.27
γ 169.0	2.32	2.20	2.35	2.30
γ 170.0	2.34	2.25	2.37	2.31
γ 171.0	2.38	2.28	2.40	2.35
γ 172.0	2.41	2.31	2.42	2.37
γ 173.0	2.44	2.35	2.45	2.40
γ 174.0	2.46	2.36	2.46	2.41
γ 175.0	2.49	2.39	2.48	2.43
γ 176.0	2.51	2.42	2.50	2.46
γ 177.0	2.51	2.44	2.50	2.48
γ 178.0	2.53	2.44	2.52	2.49
γ 179.0	2.53	2.45	2.52	2.49
γ 180.0	2.52	2.52	2.52	2.52