IES Indoor Report
Photometric Filename:HCP-10X1201 2700K 60D.IES

Indoor Luminaire Photometric Data


Description Information

Luminary Name: HCP-10X1201 2700K 60D		Lum. Catelog:	Test ID: 01
Lamp Name:		Lamp Catelog: LED	Test Date: 2022/11/01
Manufacture: Havit Commercial		Shld.Ang(°):	Test Machine:GON-2000
Test Lab: Quality Department		Frequency(Hz):	Lamp CCT(K): Ra:
Lum.Size(W*L*H):0.041m*0.041m*0.000m		Lum.Area(m2):0.002	Lum.W(kg): 0.000
Test System: C, γ	Test Step: C=90.0 γ=5.0	Temp.(℃): 25	Humidity(%):


Character Parameter

Lamp Speciality Parameter	Luminaire Speciality Parameter	
Rated Flux(lm): 759.850	Luminary Flux(lm): 759.851	Field Angle(10%Imax): 91.7(°)
Rated Power(W):	Luminary Efficiency: 100.00%	Down Lumens&Percent: 758.7101m 99.85%
Rated Voltage(V):	Luminary EER(lm/W): 63.639	Up Lumens&Percent: 1.1401m 0.15%
Tested Power(W): 11.940	Max.Candela(cd): 794.494	S/MH: C0_a180=0.904 C90_270=0.896
Lamps' Inside: 1	Max Cand@Ang.(°): C=0.0 γ=0.0	CIE Type: Semi-Direct
Tested Electrics(V,A,pf):230.1,0.054	Beam Angle(50%Imax): 58.6(°)	ErP Φuse(90°): 690.686lm
Lamp Size(W*L*H):0.041m*0.041m*0.000m	Left=-28.9° ,Right=29.7°	IRF(%): 225.335

C Plane Distribution Diagram



C0 Space ISO Illuminance Curve





IES Indoor Report
Photometric Filename:HCP-10X1201 2700K 60D.IES

2D Plane Light Intensity Distribution Curve

Lum.Name: HCP-10X1201 2700K 60D	Lum.Catelog:	Test ID: 01
Lamp Name:	Lamp Catelog: LED	Test Lab: Quality Department
Manufacture: Havit Commercial	Test Machine:GON-2000	Test Date: 2022/11/01

C Plane Distribution Diagram






C Plane	[50%MaxAng.]	[10%MaxAng.]	Unit:cd
C0.0_180.0 :	58.6	91.7	
C90.0_270.0 :	58.1	92.2	

IES Indoor Report
Photometric Filename:HCP-10X1201 2700K 60D.IES

3D Light Intensity Distribution Modal

Lum.Name: HCP-10X1201 2700K 60D	Lum.Catelog:	Test ID: 01
Lamp Name:	Lamp Catelog: LED	Test Lab: Quality Department
Manufacture: Havit Commercial	Test Machine:GON-2000	Test Date: 2022/11/01

3D Light Intensity Distribution Modal



Curves: 3D Model Fixture Vert. HUD Hori. HUD

View Angles: Orient:0 Tilt:0 Roll:0 Spin:0

IES Indoor Report
Photometric Filename:HCP-10X1201 2700K 60D.IES


Zonal Flux Tabulation

Zone(γ)	Zone Flux (lm)	Sums Flux (lm)	Zone%Lamp	Sums%Lamp
0.0-5.0	18.87	18.87	2.48	2.48
5.0-10.0	54.79	73.66	7.21	9.69
10.0-15.0	85.42	159.08	11.24	20.94
15.0-20.0	107.56	266.64	14.16	35.09
20.0-25.0	117.44	384.08	15.46	50.55
25.0-30.0	111.70	495.78	14.70	65.25
30.0-35.0	91.61	587.40	12.06	77.30
35.0-40.0	65.88	653.27	8.67	85.97
40.0-45.0	43.92	697.20	5.78	91.75
45.0-50.0	26.49	723.69	3.49	95.24
50.0-55.0	13.66	737.35	1.80	97.04
55.0-60.0	7.97	745.32	1.05	98.09
60.0-65.0	5.52	750.85	0.73	98.82
65.0-70.0	3.57	754.42	0.47	99.29
70.0-75.0	2.32	756.74	0.31	99.59
75.0-80.0	1.34	758.08	0.18	99.77
80.0-85.0	0.55	758.63	0.07	99.84
85.0-90.0	0.08	758.71	0.01	99.85
90.0-95.0	0.00	758.71	0.00	99.85
95.0-100.0	0.00	758.71	0.00	99.85
100.0-105.0	0.00	758.71	0.00	99.85
105.0-110.0	0.00	758.71	0.00	99.85
110.0-115.0	0.00	758.71	0.00	99.85
115.0-120.0	0.00	758.71	0.00	99.85
120.0-125.0	0.00	758.71	0.00	99.85
125.0-130.0	0.00	758.71	0.00	99.85
130.0-135.0	0.00	758.71	0.00	99.85
135.0-140.0	0.00	758.71	0.00	99.85
140.0-145.0	0.02	758.73	0.00	99.85
145.0-150.0	0.08	758.80	0.01	99.86
150.0-155.0	0.18	758.98	0.02	99.89
155.0-160.0	0.25	759.23	0.03	99.92
160.0-165.0	0.24	759.47	0.03	99.95
165.0-170.0	0.20	759.67	0.03	99.98
170.0-175.0	0.13	759.80	0.02	99.99
175.0-180.0	0.05	759.85	0.01	100.00

IES Indoor Report
Photometric Filename:HCP-10X1201 2700K 60D.IES

Rectangle ISO Lighting Intensity Diagram

Lum.Name: HCP-10X1201 2700K 60D	Lum.Catelog:	Test ID: 01
Lamp Name:	Lamp Catelog: LED	Test Lab: Quality Department
Manufacture: Havit Commercial	Test Machine:GON-2000	Test Date: 2022/11/01




Maximum Light Intensity(cd): 794.49
Maximum Cand.@Angle: H=0.0°,V=0.0°

IES Indoor Report
Photometric Filename:HCP-10X1201 2700K 60D.IES

Plane ISO-Illuminance Diagram

Lum.Name: HCP-10X1201 2700K 60D	Lum.Catelog:	Test ID: 01
Lamp Name:	Lamp Catelog: LED	Test Lab: Quality Department
Manufacture: Havit Commercial	Test Machine:GON-2000	Test Date: 2022/11/01

Plane ISO-Illuminance Curve




Working Plane Luminaire Mounting Height(m): 3.00
Working Plane Maximum Illuminance(lx): 88.28
Working Plane Maximum Illuminance Position(d/h):H0.0 V0.0

IES Indoor Report
Photometric Filename:HCP-10X1201 2700K 60D.IES

3D Plane ISO Illuminance Diagram

Lum.Name: HCP-10X1201 2700K 60D	Lum.Catelog:	Test ID: 01
Lamp Name:	Lamp Catelog: LED	Test Lab: Quality Department
Manufacture: Havit Commercial	Test Machine:GON-2000	Test Date: 2022/11/01

3D Plane Illuminance Modal



Curves: 3D Model 90% 80% 70% 60% 50% 40% 30% 20% 10%


View Angles(deg): 0 Height(m): 3.0 Distance(m): 10.0

IES Indoor Report
Photometric Filename:HCP-10X1201 2700K 60D.IES

Space ISO Illuminance Diagram

Lum.Name: HCP-10X1201 2700K 60D	Lum.Catelog:	Test ID: 01
Lamp Name:	Lamp Catelog: LED	Test Lab: Quality Department
Manufacture: Havit Commercial	Test Machine:GON-2000	Test Date: 2022/11/01

Space ISO Illuminance Curve




Space Plane Maximum Illuminance and @Angle:794.49lx,0.0deg
Plane Maximum Lighting Intensity and @Angle:794.494cd,0eg

IES Indoor Report
Photometric Filename:HCP-10X1201 2700K 60D.IES

Illuminance-Distance Diagram

Lum.Name: HCP-10X1201 2700K 60D	Lum.Catelog:	Test ID: 01
Lamp Name:	Lamp Catelog: LED	Test Lab: Quality Department
Manufacture: Havit Commercial	Test Machine:GON-2000	Test Date: 2022/11/01

Illuminance-Distance Curve



Beam Angle:58.6

IES Indoor Report
Photometric Filename:HCP-10X1201 2700K 60D.IES

Indoor Luminance Limiting Curves

Lum.Name: HCP-10X1201 2700K 60D	Lum.Catelog:	Test ID: 01
Lamp Name:	Lamp Catelog: LED	Test Lab: Quality Department
Manufacture: Havit Commercial	Test Machine:GON-2000	Test Date: 2022/11/01


Glare Grade Table

GI	Quality	Using Illuminace							
1.15	A	2000	1000	500	<=300				
1.5	B		2000	1000	500	<=300			
1.85	C			2000	1000	500	<=300		
2.2	D				2000	1000	500	<=300	
2.55	E	a				2000	1000	500	<=300
			b	c	d	e	f	g	h

Luminance Table

Gama(deg)	45	50	55	60	65	70	75	80	85
C0	77806	39512	22241	17920	12811	9919	7881	5659	0
C90	70823	35197	21270	17255	11824	8914	6298	4748	0

Luminance Limiting Curve



Luminous Size: Length(m)=0.041 Width(m)=0.041 Height(m)=0.000 Area(m^2)=0.001681


Luminous Type: Without Luminous Side

Luminous Curves: C0-C180 Color: C90-C270 Color:

IES Indoor Report
Photometric Filename:HCP-10X1201 2700K 60D.IES

Indoor Budgetary Estimate Table

Lum.Name: HCP-10X1201 2700K 60D	Lum.Catelog:	Test ID: 01
Lamp Name:	Lamp Catelog: LED	Test Lab: Quality Department
Manufacture: Havit Commercial	Test Machine:GON-2000	Test Date: 2022/11/01



Parameters1: Rhocc = 0.7 Rhow = 0.5 Rhofc = 0.2 LLF = 0.8
Parameters2: Rhocc = 0.5 Rhow = 0.3 Rhofc = 0.2 LLF = 0.8
Average Illuminance(lx): 100 Cavity Height: H1(m) = 2

IES Indoor Report
Photometric Filename:HCP-10X1201 2700K 60D.IES

Indoor Coefficient of Utilization Table

Lum.Name: HCP-10X1201 2700K 60D	Lum.Catelog:	Test ID: 01
Lamp Name:	Lamp Catelog: LED	Test Lab: Quality Department
Manufacture: Havit Commercial	Test Machine:GON-2000	Test Date: 2022/11/01

Coefficients of Utilization - Zonal Cavity Method																		
Coef.	Effective Floor Cavity Reflectance RFC=0.20																	
RhoCC(%)	80				70				50			30			10			0
RhoW(%)	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	0
RCR	Coefficient of Utilization(%)																	
0	119	119	119	119	116	116	116	116	111	111	111	106	106	106	102	102	102	100
1	113	110	107	105	111	108	106	103	104	102	100	100	99	97	97	95	94	93
2	107	102	98	94	105	100	96	93	97	94	91	94	91	89	91	89	87	85
3	101	94	89	85	99	93	88	84	90	86	83	88	84	81	85	83	80	79
4	96	88	82	77	94	86	81	77	84	80	76	82	78	75	80	77	74	72
5	91	82	75	71	89	81	75	71	79	74	70	77	73	69	76	72	69	67
6	86	76	70	65	84	75	70	65	74	69	65	72	68	64	71	67	64	62
7	81	71	65	61	80	71	65	60	69	64	60	68	63	60	67	63	59	58
8	77	67	61	56	76	66	60	56	65	60	56	64	59	56	63	59	56	54
9	73	63	57	53	72	63	57	53	62	56	52	61	56	52	60	55	52	51
10	70	60	53	49	69	59	53	49	58	53	49	57	53	49	57	52	49	48

IES Indoor Report
Photometric Filename:HCP-10X1201 2700K 60D.IES

Unified Glare Rating Table

Lum.Name: HCP-10X1201 2700K 60D	Lum.Catelog:	Test ID: 01
Lamp Name:	Lamp Catelog: LED	Test Lab: Quality Department
Manufacture: Havit Commercial	Test Machine:GON-2000	Test Date: 2022/11/01

Unified Glare Rating Table

Ceiling RCC		0.70	0.70	0.50	0.50	0.30	0.70	0.70	0.50	0.50	0.30
Wall RW		0.50	0.30	0.50	0.30	0.30	0.50	0.30	0.50	0.30	0.30
Floor RFC		0.20	0.20	0.20	0.20	0.20	0.20	0.20	0.20	0.20	0.20
Room Size		Vewed crosswise					Vewed endwise				
X=2H	Y=2H	23.5	24.5	23.8	24.8	25.2	22.9	24.0	23.3	24.3	24.7
	Y=3H	23.4	24.3	23.8	24.7	25.0	22.9	23.8	23.3	24.2	24.5
	Y=4H	23.3	24.2	23.7	24.6	25.0	22.8	23.7	23.2	24.1	24.4
	Y=6H	23.3	24.1	23.7	24.4	24.8	22.7	23.5	23.2	23.9	24.3
	Y=8H	23.2	24.0	23.6	24.4	24.8	22.7	23.5	23.1	23.8	24.3
	Y=12H	23.2	23.9	23.6	24.3	24.7	22.6	23.4	23.1	23.7	24.2
X=4H	Y=2H	23.3	24.1	23.7	24.5	24.9	22.8	23.7	23.2	24.0	24.4
	Y=3H	23.2	24.0	23.7	24.4	24.8	22.7	23.5	23.1	23.9	24.3
	Y=4H	23.2	23.8	23.6	24.3	24.7	22.7	23.3	23.1	23.7	24.2
	Y=6H	23.1	23.7	23.6	24.1	24.6	22.6	23.2	23.1	23.6	24.1
	Y=8H	23.1	23.6	23.5	24.0	24.5	22.5	23.1	23.0	23.5	24.0
	Y=12H	23.0	23.5	23.5	24.0	24.4	22.5	22.9	23.0	23.4	23.9
X=8H	Y=4H	23.0	23.6	23.5	24.0	24.5	22.5	23.1	23.0	23.5	24.0
	Y=6H	23.0	23.4	23.5	23.9	24.4	22.5	22.9	23.0	23.4	23.9
	Y=8H	22.9	23.3	23.5	23.8	24.3	22.4	22.8	22.9	23.3	23.8
	Y=12H	22.9	23.2	23.4	23.7	24.3	22.4	22.7	22.9	23.2	23.8
X=12H	Y=4H	23.0	23.4	23.5	23.9	24.4	22.5	22.9	23.0	23.4	23.9
	Y=6H	22.9	23.3	23.5	23.8	24.3	22.4	22.8	22.9	23.3	23.8
	Y=8H	22.9	23.2	23.4	23.7	24.3	22.4	22.7	22.9	23.2	23.8
Variations with the objerver position at spacings											
S=1.0H		0.8/-0.9					0.8/-0.9				
S=1.5H		1.4/-1.6					1.5/-1.7				
S=2.0H		2.0/-2.5					2.2/-2.8				
Reduced UGR Table:											
Nordic Standard Table:		BK0					BK0				
Correction Value		0.2					0.2				

o the CIE Pub.117,data has been corrected,refers to the lamp's lumens 8.2flm.

IES Indoor Report
Photometric Filename:HCP-10X1201 2700K 60D.IES

Candela Tabulation

V/H	C0.0	C90.0	C180.0	C270.0
γ 0.0	794.49	794.49	794.49	794.49
γ 5.0	788.59	780.96	776.91	788.05
γ 10.0	759.77	737.98	735.68	758.62
γ 15.0	707.93	680.14	678.67	701.46
γ 20.0	630.94	596.75	599.65	624.89
γ 25.0	524.77	487.94	495.92	518.15
γ 30.0	389.96	357.85	368.08	387.92
γ 35.0	256.24	231.63	240.33	256.52
γ 40.0	154.46	140.15	142.83	157.28
γ 45.0	92.48	84.18	82.47	95.03
γ 50.0	42.69	38.03	40.28	49.26
γ 55.0	21.44	20.51	18.43	20.68
γ 60.0	15.06	14.50	13.08	14.22
γ 65.0	9.10	8.40	7.88	8.66
γ 70.0	5.70	5.13	5.44	6.12
γ 75.0	3.43	2.74	3.55	3.44
γ 80.0	1.65	1.39	1.83	1.96
γ 85.0	0.00	0.00	0.57	0.66
γ 90.0	0.00	0.00	0.00	0.00
γ 95.0	0.00	0.00	0.00	0.00
γ 100.0	0.00	0.00	0.00	0.00
γ 105.0	0.00	0.00	0.00	0.00
γ 110.0	0.00	0.00	0.00	0.00
γ 115.0	0.00	0.00	0.00	0.00
γ 120.0	0.00	0.00	0.00	0.00
γ 125.0	0.00	0.00	0.00	0.00
γ 130.0	0.00	0.00	0.00	0.00
γ 135.0	0.00	0.00	0.00	0.00
γ 140.0	0.00	0.00	0.00	0.00
γ 145.0	0.00	0.00	0.26	0.13
γ 150.0	0.42	0.35	0.44	0.46
γ 155.0	0.69	1.05	0.92	1.21
γ 160.0	1.43	1.22	1.41	1.53
γ 165.0	1.56	1.49	1.87	1.28
γ 170.0	1.76	1.68	1.92	1.83
γ 175.0	1.89	1.81	2.16	1.89
γ 180.0	2.22	2.22	2.22	2.22